



- NOTES:
1. THE EMERGENCY DIESEL GENERATOR FUEL OIL TANKS AREA FIRE PROTECTION SYSTEM (DELLS SYSTEM) HAS BEEN PURCHASED UNDER FSC-2025, UNIT 2 ELECTRICAL GROUP TO PROVIDE WIRING FOR CONTROLS.
 2. SEE M-2219, SH. 4, FOR TYPICAL TRIM DETAILS FOR UNIT 1 AND M-2219, SH. 4, FOR TYPICAL TRIM DETAILS.
 3. SH-7 IS CONNECTED TO THE CITY DOMESTIC WATER SUPPLY AND IS NOT INSTALLED ON THE AND FIREWATER SYSTEM. SH-7 IS LOCATED BESIDE THE INCENDIAR BUILDING NORTH OF THE MAINTENANCE FACILITY.
 4. FS-140 WAS INSTALLED FOR FUTURE EXPANSION TO THE FIREWATER SYSTEM IN THE SWITCH YARD.
 5. VALVES THAT ARE IN PHANTOM ARE LOCATED ON M-219 FIRE WATER P&ID. THE VALVES ARE SHOWN ON THIS DRAWING FOR REFERENCE ONLY.
 6. SEE YELLOW DOWING M-219 FOR LOADING DOCK SPRINKLER DETAILS.
 7. DELETED.
 8. VALVES FS-67 AND FS-77 WERE ABANDONED IN PLACE BY DCP 89-2825-A.

LEGEND			
—	LINE COLOR	SYSTEM/AMR REPORT	
—		WATER SUPPRESSION FIRE PROTECTION/82-R-2005-08	
		LICENSE RENEWAL BOUNDARY	
ARKANSAS NUCLEAR ONE			
UNIT 2			
RUSSELLVILLE, ARKANSAS			
PIPING & INSTRUMENT DIAGRAM			
UNIT ONE / UNIT TWO			
OUTSIDE FIRE WATER LOOP			
DRAWING NO		SHEET	REVISION
LRA-M-2219		5	0

 Entergy

SED ON M-2219 SH 5 REV 481

RED ** IF ORIGINAL