

3.7 PLANT SYSTEMS

3.7.9 Control Room Emergency Filtration System (CREFS)

LCO 3.7.9 CREFS shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, 4,
During movement of irradiated fuel assemblies,
During CORE ALTERATIONS.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. CREFS inoperable.	A.1 Restore CREFS to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	B.2 Suspend movement of irradiated fuel assemblies.	Immediately
	<u>AND</u>	
	B.3 Be in MODE 3.	6 hours
	<u>AND</u>	
	B.4 Be in MODE 5.	36 hours