



OCT 09 2003

L-2003-256  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report - September 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the September 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Terry O. Jones  
Vice President  
Turkey Point Plant

LDT

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

JE24

DOCKET NO.: 50-250  
 UNIT: Turkey Point Unit 3  
 DATE: 10/02/2003  
 COMPLETED BY: Linda Tudor  
 TELEPHONE: (305) 246-6408

Reporting Period September, 2003

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720.0	5784.8	200324.2
No. of hours generator was on line (service hours)	720.0	5742.8	197951
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	504925	3913933	129273010

### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

#### (1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

#### (2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

### Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power until September 29 when power was reduced to approximately 90% due to reduction in condenser vacuum. Unit 3 returned to 100% power on September 30.

DOCKET NO.: 50-251  
 UNIT: Turkey Point Unit 4  
 DATE: 10/02/03  
 COMPLETED BY: Linda Tudor  
 TELEPHONE: (305) 246-6408

Reporting Period September, 2003

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720.0	6551	197913.7
No. of hours generator was on line (service hours)	720.0	6551	193496.2
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	492460	4557716	127516806

#### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

##### (1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

##### (2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

#### Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power until September 21 when the unit initiated a Tavg/Power Coastdown in preparation for the refueling outage.