

NRC 2003-0093


GL 97-02

October 13, 2003

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

POINT BEACH NUCLEAR PLANT  
DOCKETS 50-266 AND 50-301  
MONTHLY OPERATING REPORT – September 2003

In accordance with Technical Specification 5.6.3, attached is the Monthly Operating Report for September 2003 for the Point Beach Nuclear Plant. Nuclear Management Company has not made new or revised commitments in this letter or the attachment.

  
A. J. Cayia  
Site Vice President  
KML

Attachment: NRC Monthly Report: September 2003

cc: Regional Administrator, Region III, USNRC  
NRC Resident Inspector - Point Beach Nuclear Plant  
Project Manager, Point Beach Nuclear Plant, NRR, USNRC  
J. D. Loock, PSCW

## OPERATING DATA REPORT

DOCKET NO. 50-266  
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1  
DATE 10/06/03  
COMPLETED BY Kim M. Locke  
TELEPHONE 920-755-6420

REPORTING PERIOD September - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET)	522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	516.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	6,337.5	237,936.9
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	6,329.2	234,387.7
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	366,330.0	3,219,164.5	108,770,473.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

# UNIT SHUTDOWNS

DOCKET NO. 50-266  
UNIT NAME: Point Beach, Unit 1  
DATE: 10/13/2003  
COMPLETED BY: Kim M. Locke  
TELEPHONE: 755-6420

REPORTING PERIOD: September 2003  
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

## (1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

## (2) Method

- 1. Manual
- 2. Manual Trip/Scram
- 3. Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

## SUMMARY:

Unit 1 average daily power for the month of September was 508.8 MWe.

There was one LER on Unit 1 in the month of September: LER 2003-002-00, Unit 1 Reactor Trip Due to Failure of 1G06 Rod Drive MG Voltage Regulator

## OPERATING DATA REPORT

DOCKET NO. 50-301  
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2  
DATE 10/06/03  
COMPLETED BY Kim M. Locke  
TELEPHONE 920-755-6420

REPORTING PERIOD September - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET)	522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	518.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	6,447.6	232,200.7
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	6,394.7	229,160.4
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	324,441.0	3,184,359.5	107,972,163.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

# UNIT SHUTDOWNS

DOCKET NO. 50-301  
UNIT NAME: Point Beach, Unit 2  
DATE: 10/13/2003  
COMPLETED BY: Kim M. Locke  
TELEPHONE: 755-6420

REPORTING PERIOD: September 2003  
(Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

## (1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

## (2) Method

- 1. Manual
- 2. Manual Trip/Scram
- 3. Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

## SUMMARY:

Unit 2 average daily power for the month of September was 450.6 MWe.  
There were no LERs on Unit 2 in the month of September.