

AmerGen Energy Company, LLC  
Oyster Creek  
US Route 9 South  
P.O. Box 388  
Forked River, NJ 08731-0388

An Exelon/British Energy Company

GL 97-02

October 15, 2003  
2130-03-20265

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555 - 0001


Oyster Creek Generating Station  
Facility Operating License No. DPR-16  
NRC Docket No. 50-219

Subject: Monthly Operating Report - September 2003

Enclosed is the September 2003 Monthly Operating Report for Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If any further information or assistance is needed, please contact William Stewart at 609-971-4775.

Sincerely,



Ernest J. Harkness P. E.  
Vice President, Oyster Creek Generating Station

EJH/WVS  
Enclosures - Operating Data Report

cc: H. J. Miller, Administrator, USNRC Region I  
P. S. Tam, USNRC Senior Project Manager, Oyster Creek  
J. Herrera, USNRC Senior Resident Inspector, Oyster Creek  
File No. 03001

JE24

## OPERATING DATA REPORT

DOCKET NO. 50-219  
 UNIT NAME Oyster Creek 1  
 DATE October 10, 2003  
 COMPLETED BY W. V. Stewart  
 TELEPHONE (609) 971-4775

REPORTING PERIOD: September 2003

1. Design Electrical Rating	650.00		
2. Maximum Dependable Capacity (MWe-Net)	619.00		
	<b>This Month</b>	<b>Yr-to-Date</b>	<b>Cumulative</b>
3. Number of Hours the Reactor was Critical	720.00	6,306.92	216,228.02
4. Number of Hours Generator On-line	720.00	6,259.45	211,986.65
5. Reserve Shutdown Hours	0.00	0.00	918.20
6. Net Electrical Energy Generated (MWHrs)	447,339.00	3,864,761.00	121,003,189.00

## UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
-----	------	-----------------------------------	---------------------	----------	---------------------------------	---------------------------------------

1

## Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

## Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY: During September, Oyster Creek generated 447,339 net MWh electric, which was 100.4% of its MDC rating.