

## INDEX

### LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS (Continued)</u>	
ACTIVITY.....	3/4 7-7
MAIN STEAM LINE ISOLATION VALVES (MSIVs).....	3/4 7-9
MAIN FEEDWATER ISOLATION VALVES .....	3/4 7-9a
3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	3/4 7-10
3/4.7.3 COMPONENT COOLING WATER AND AUXILIARY COMPONENT COOLING WATER SYSTEMS.....	3/4 7-11
3/4.7.4 ULTIMATE HEAT SINK.....	3/4 7-12
3/4.7.5 FLOOD PROTECTION.....	3/4 7-15
3/4.7.6 CONTROL ROOM AIR CONDITIONING SYSTEM.....	3/4 7-16
CONTROL ROOM EMERGENCY AIR FILTRATION SYSTEM - OPERATING.....	3/4 7-16
CONTROL ROOM EMERGENCY AIR FILTRATION SYSTEM - SHUTDOWN.....	3/4 7-18
CONTROL ROOM AIR TEMPERATURE - OPERATING	3/4 7-18a
CONTROL ROOM AIR TEMPERATURE - SHUTDOWN	3/4 7-18b
CONTROL ROOM ISOLATION AND PRESSURIZATION	3/4 7-18c
3/4.7.7 CONTROLLED VENTILATION AREA SYSTEM.....	3/4 7-19
3/4.7.8 SNUBBERS.....	3/4 7-21
3/4.7.9 SEALED SOURCE CONTAMINATION.....	3/4 7-27
3/4.7.12 ESSENTIAL SERVICES CHILLED WATER SYSTEM.....	3/4 7-43
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 A.C. SOURCES	
OPERATING.....	3/4 8-1
SHUTDOWN.....	3/4 8-8
3/4.8.2 D.C. SOURCES	
OPERATING.....	3/4 8-9
SHUTDOWN.....	3/4 8-12

## CONTAINMENT SYSTEMS

### 3/4.6.3 CONTAINMENT ISOLATION VALVES

#### LIMITING CONDITION FOR OPERATION

---

3.6.3 Each containment isolation valve shall be OPERABLE.\*

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With one or more of the isolation valve(s) inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and either:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange; or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of Specification 3.0.4 do not apply.

\* Locked or sealed closed valves may be opened on an intermittent basis under administrative control.

#### SURVEILLANCE REQUIREMENTS

---

4.6.3.1 Each containment isolation valve shall be demonstrated OPERABLE prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by performance of a cycling test and verification of isolation time.

## PLANT SYSTEMS

### MAIN STEAM LINE ISOLATION VALVES (MSIVs)

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.5 Two MSIVs shall be OPERABLE.

APPLICABILITY: MODE 1, and  
MODES 2, 3, and 4, except when all MSIVs are closed and deactivated.

#### ACTION:

##### MODE 1

With one MSIV inoperable, restore the valve to OPERABLE status within 8 hours or be in STARTUP within the next 6 hours.

##### MODES 2, 3 and 4

With one MSIV inoperable, close the valve within 8 hours and verify the valve is closed once per 7 days. Otherwise, be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

Note: Required to be performed for entry into MODES 1 and 2 only.

4.7.1.5 Each MSIV shall be demonstrated OPERABLE:

- a. By verifying full closure within 4.0 seconds when tested pursuant to the Inservice Testing Program.
- b. By verifying each MSIV actuates to the isolation position on an actual or simulated actuation signal at least once per 18 months.