

James H. Lash
Plant General Manager

724-682-7773

October 15, 2003
L-03-150

Kareen Milcic
Pennsylvania Department of Environmental Protection
Southwest Region
400 Waterfront Drive
Pittsburgh, PA 15222-4745

**Report of Additional Monitoring Conducted at Internal Monitoring Points 113 & 203
for Beaver Valley Power Station, NPDES Permit No PA0025615**

Dear Ms. Milcic:

During a recent data trend review, we discovered that additional monitoring has been conducted at NPDES Permit No. PA0025615, Internal Monitoring Point (IMP) 113 - Unit 2 Sewage Treatment Plant, and IMP 203 - Unit 1 Sewage Treatment Plant, for Total Residual Chlorine (TRC). The additional monitoring was established several years ago to ensure optimal performance of the plants regarding treatment for fecal coliform, while maintaining TRC within Permit limits. It was only during the recent data review that we discovered that the performance monitoring samples were taken at the same point, and analyzed with the same methods as those required in the Permit.

Therefore, in accordance with the Permit, Part A- Reporting of Monitoring Requirements, Paragraph (4), we are submitting the attached additional monitoring report. The report lists the sample dates, results, maximum values, and re-calculated monthly averages for TRC, for those months since December 1999 in which the additional monitoring was conducted. The review of that data indicates that there were no exceedances of Monthly Average or Maximum Permit Limits for the additional sampling events. There was, however, one occurrence on September 27, 2000 in which the result of 4.3 mg/l exceeded the Maximum limit of 3.3 mg/l. This occurrence was reported with the September 2000 Discharge Monitoring Reports (DMR) under our letter number NPD3VPO: 1140 and dated October 27, 2000.

The issue of additional monitoring is being investigated and documented in the FENOC Process Improvement Program under Condition Report CR-03-09180. A preliminary


JE25

Report of Additional Monitoring Conducted at Internal Monitoring
Points 113 and 203 for Beaver Valley Power Station
L-03-150
Page 2

review of procedures did not reveal any other required-to-be reported additional monitoring at Beaver Valley Power Station. Corrective actions will be taken and documented also in the condition report.

Should you have any questions, please direct them to Mr. Edward Hubley, Manager Nuclear Environmental & Chemistry, at 724-682-7340.

Sincerely,



James H. Lash
Plant General Manager

Attachment

c: DMR Clerk, PA DEP
Document Control Desk US NRC
US Environmental Protection Agency

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	MONITORING	RESULT
Recalculated TRC Monthly Average					
NPDES 203	Unit 1 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.320
				Dec-99 Average	0.425
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.560
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.430
				Jan-00 Average	0.495
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	29-Feb-00	Feb-00	0.600
				Feb-00 Average	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.700
NPDES 203	Unit 1 STP	Chlorine, TRC	28-Mar-00	Mar-00	0.600
				Mar-00 Average	0.650
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.800
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Apr-00	Apr-00	0.950
				Apr-00 Average	0.875
NPDES 203	Unit 1 STP	Chlorine, TRC	02-May-00	May-00	0.510
NPDES 203	Unit 1 STP	Chlorine, TRC	09-May-00	May-00	0.550
				May-00 Average	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Jun-00	Jun-00	0.710
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Jun-00	Jun-00	0.560
				Jun-00 Average	0.635
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-00	Jul-00	0.450
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jul-00	Jul-00	0.600
				Jul-00 Average	0.525
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Aug-00	Aug-00	0.700
NPDES 203	Unit 1 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.600
				Aug-00 Average	0.650
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	04-Sep-00	Sep-00	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Sep-00	Sep-00	1.000
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Sep-00	Sep-00	0.350
NPDES 203	Unit 1 STP	Chlorine, TRC	27-Sep-00	Sep-00	2.200
				Sep-00 Average	1.038
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Oct-00	Oct-00	0.150
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Oct-00	Oct-00	0.550
				Oct-00 Average	0.350
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Nov-00	Nov-00	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.320
				Nov-00 Average	0.495
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Dec-00	Dec-00	0.960
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.770

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYST	SAMPLEDATE	Month	RESULT
				Dec-00 Average	0.865
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jan-01	Jan-01	0.470
NPDES 203	Unit 1 STP	Chlorine, TRC	23-Jan-01	Jan-01	0.560
				Jan-01 Average	0.515
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Feb-01	Feb-01	0.410
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Feb-01	Feb-01	0.670
				Feb-01 Average	0.540
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Mar-01	Mar-01	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	20-Mar-01	Mar-01	0.340
				Mar-01 Average	0.390
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Apr-01	Apr-01	0.750
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Apr-01	Apr-01	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	17-Apr-01	Apr-01	0.300
				Apr-01 Average	0.573
NPDES 203	Unit 1 STP	Chlorine, TRC	22-May-01	May-01	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	29-May-01	May-01	0.290
				May-01 Average	0.165
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Jun-01	Jun-01	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	27-Jun-01	Jun-01	0.080
				Jun-01 Average	0.210
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.140
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.140
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Jul-01	Jul-01	0.110
				Jul-01 Average	0.130
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Aug-01	Aug-01	0.800
NPDES 203	Unit 1 STP	Chlorine, TRC	29-Aug-01	Aug-01	0.170
				Aug-01 Average	0.485
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Sep-01	Sep-01	0.070
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Sep-01	Sep-01	0.050
				Sep-01 Average	0.060
NPDES 203	Unit 1 STP	Chlorine, TRC	16-Oct-01	Oct-01	0.110
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Oct-01	Oct-01	0.450
				Oct-01 Average	0.280
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	08-Nov-01	Nov-01	0.100
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Nov-01	Nov-01	1.130
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.480
				Nov-01 Average	0.570
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Dec-01	Dec-01	0.350
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.520
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	31-Dec-01	Dec-01	0.130

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
				Dec-01 Average	0.333
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Jan-02	Jan-02	0.500
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.120
				Jan-02 Average	0.310
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Feb-02	Feb-02	0.050
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	07-Feb-02	Feb-02	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.060
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	23-Feb-02	Feb-02	0.160
				Feb-02 Average	0.078
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	02-Mar-02	Mar-02	0.080
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Mar-02	Mar-02	0.490
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	07-Mar-02	Mar-02	0.120
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	16-Mar-02	Mar-02	0.060
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Mar-02	Mar-02	0.280
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	27-Mar-02	Mar-02	0.160
				Mar-02 Average	0.198
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Apr-02	Apr-02	0.070
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	04-Apr-02	Apr-02	0.180
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	12-Apr-02	Apr-02	0.250
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Apr-02	Apr-02	0.250
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	27-Apr-02	Apr-02	0.240
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Apr-02	Apr-02	0.200
				Apr-02 Average	0.198
NPDES 203	Unit 1 STP	Chlorine, TRC	10-May-02	May-02	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	12-May-02	May-02	0.480
				May-02 Average	0.515
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Jun-02	Jun-02	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jun-02	Jun-02	0.550
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Jun-02	Jun-02	0.220
				Jun-02 Average	0.433
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jul-02	Jul-02	0.320
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	06-Jul-02	Jul-02	0.540
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	13-Jul-02	Jul-02	0.460
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	15-Jul-02	Jul-02	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jul-02	Jul-02	0.280
				Jul-02 Average	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Aug-02	Aug-02	0.540
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Aug-02	Aug-02	0.110
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Aug-02	Aug-02	1.180
				Aug-02 Average	0.610
NPDES 203	Unit 1 STP	Chlorine, TRC	02-Sep-02	Sep-02	2.480
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Sep-02	Sep-02	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	23-Sep-02	Sep-02	0.780
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Sep-02	Sep-02	1.080

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
				Sep-02 Average	1.223
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Oct-02	Oct-02	0.620
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Oct-02	Oct-02	0.360
				Oct-02 Average	0.490
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Nov-02	Nov-02	0.130
NPDES 203	Unit 1 STP	Chlorine, TRC	15-Nov-02	Nov-02	0.030
				Nov-02 Average	0.080
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Dec-02	Dec-02	0.070
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	10-Dec-02	Dec-02	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Dec-02	Dec-02	0.180
				Dec-02 Average	0.197
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jan-03	Jan-03	0.180
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.150
				Jan-03 Average	0.165
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Feb-03	Feb-03	0.380
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Feb-03	Feb-03	0.300
				Feb-03 Average	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Mar-03	Mar-03	0.360
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.220
				Mar-03 Average	0.790
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Apr-03	Apr-03	0.520
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Apr-03	Apr-03	0.030
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	15-Apr-03	Apr-03	0.060
NPDES 203	Unit 1 STP	Chlorine, TRC	16-Apr-03	Apr-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	16-Apr-03	Apr-03	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.440
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.440
				Apr-03 Average	0.224
NPDES 203	Unit 1 STP	Chlorine, TRC	05-May-03	May-03	0.290
NPDES 203	Unit 1 STP	Chlorine, TRC	22-May-03	May-03	2.070
				May-03 Average	1.180
NPDES 203	Unit 1 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.110
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.110
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Jun-03	Jun-03	2.900
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Jun-03	Jun-03	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	30-Jun-03	Jun-03	0.240
				Jun-03 Average	0.554
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jul-03	Jul-03	0.080
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	10-Jul-03	Jul-03	0.380
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Jul-03	Jul-03	0.600
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	17-Jul-03	Jul-03	0.620

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	22-Jul-03	Jul-03	0.540
				Jul-03 Average	0.444
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	01-Aug-03	Aug-03	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Aug-03	Aug-03	0.200
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Aug-03	Aug-03	0.490
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Aug-03	Aug-03	0.530
				Aug-03 Average	0.390
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Dec-99	Dec-99	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Dec-99	Dec-99	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Dec-99	Dec-99	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Dec-99	Dec-99	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Dec-99	Dec-99	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.480
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.480
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Dec-99	Dec-99	0.640
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Dec-99	Dec-99	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Dec-99	Dec-99	0.820
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Dec-99	Dec-99	0.910
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Dec-99	Dec-99	0.770
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Dec-99	Dec-99	0.700
				Dec-99 Average	0.612
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Jan-00	Jan-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Jan-00	Jan-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jan-00	Jan-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Jan-00	Jan-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jan-00	Jan-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Jan-00	Jan-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Jan-00	Jan-00	0.560
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Jan-00	Jan-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Jan-00	Jan-00	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Jan-00	Jan-00	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jan-00	Jan-00	0.170
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Jan-00	Jan-00	0.570

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Jan-00	Jan-00	0.530
				Jan-00 Average	0.526
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Feb-00	Feb-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Feb-00	Feb-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Feb-00	Feb-00	0.560
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Feb-00	Feb-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Feb-00	Feb-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Feb-00	Feb-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Feb-00	Feb-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Feb-00	Feb-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Feb-00	Feb-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Feb-00	Feb-00	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Feb-00	Feb-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Feb-00	Feb-00	0.500
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Feb-00	Feb-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Feb-00	Feb-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-Feb-00	Feb-00	0.650
				Feb-00 Average	0.555
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Mar-00	Mar-00	0.620
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Mar-00	Mar-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Mar-00	Mar-00	0.850
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Mar-00	Mar-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Mar-00	Mar-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Mar-00	Mar-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Mar-00	Mar-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	28-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Mar-00	Mar-00	0.800
				Mar-00 Average	0.693
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Apr-00	Apr-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Apr-00	Apr-00	0.600

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Apr-00	Apr-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Apr-00	Apr-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Apr-00	Apr-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Apr-00	Apr-00	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Apr-00	Apr-00	0.910
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Apr-00	Apr-00	0.760
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Apr-00	Apr-00	0.500
				Apr-00 Average	0.752
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-May-00	May-00	0.840
2NPDES 113	Unit 2 STP	Chlorine, TRC	02-May-00	May-00	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-May-00	May-00	0.780
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-May-00	May-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-May-00	May-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-00	May-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-00	May-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-May-00	May-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-May-00	May-00	0.550
				May-00 Average	0.609
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jun-00	Jun-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Jun-00	Jun-00	0.820
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Jun-00	Jun-00	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Jun-00	Jun-00	0.950
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Jun-00	Jun-00	0.810
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jun-00	Jun-00	0.800
				Jun-00 Average	0.748
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jul-00	Jul-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jul-00	Jul-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jul-00	Jul-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Jul-00	Jul-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Jul-00	Jul-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	31-Jul-00	Jul-00	0.600
				Jul-00 Average	0.592
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Aug-00	Aug-00	0.700
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Aug-00	Aug-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Aug-00	Aug-00	0.700
2NPDES 113	Unit 2 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Aug-00	Aug-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Aug-00	Aug-00	0.600
				Aug-00 Average	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Sep-00	Sep-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Sep-00	Sep-00	1.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Sep-00	Sep-00	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Sep-00	Sep-00	0.170
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Sep-00	Sep-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Sep-00	Sep-00	0.550

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
2NPDES 113	Unit 2 STP	Chlorine, TRC	27-Sep-00	Sep-00	4.300
				Sep-00 Average	1.151
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Oct-00	Oct-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Oct-00	Oct-00	0.380
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Oct-00	Oct-00	0.210
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Oct-00	Oct-00	0.690
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Oct-00	Oct-00	0.650
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Oct-00	Oct-00	0.370
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Oct-00	Oct-00	0.120
				Oct-00 Average	0.431
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Nov-00	Nov-00	0.160
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Nov-00	Nov-00	0.540
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.440
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.130
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Nov-00	Nov-00	0.670
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Nov-00	Nov-00	0.450
				Nov-00 Average	0.398
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Dec-00	Dec-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Dec-00	Dec-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Dec-00	Dec-00	0.750
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.650
				Dec-00 Average	0.650
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jan-01	Jan-01	0.860
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jan-01	Jan-01	0.860
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Jan-01	Jan-01	0.400
2NPDES 113	Unit 2 STP	Chlorine, TRC	23-Jan-01	Jan-01	0.840
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jan-01	Jan-01	0.560
				Jan-01 Average	0.704
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Feb-01	Feb-01	0.470
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Feb-01	Feb-01	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Feb-01	Feb-01	0.390
				Feb-01 Average	0.470
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Mar-01	Mar-01	0.290
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Mar-01	Mar-01	0.100
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Mar-01	Mar-01	0.230
2NPDES 113	Unit 2 STP	Chlorine, TRC	20-Mar-01	Mar-01	0.150
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Mar-01	Mar-01	0.140
				Mar-01 Average	0.182
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Apr-01	Apr-01	0.650
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Apr-01	Apr-01	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Apr-01	Apr-01	0.710
2NPDES 113	Unit 2 STP	Chlorine, TRC	17-Apr-01	Apr-01	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Apr-01	Apr-01	0.530
				Apr-01 Average	0.518

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-May-01	May-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-May-01	May-01	0.180
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-May-01	May-01	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-May-01	May-01	0.240
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-May-01	May-01	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-May-01	May-01	0.520
				May-01 Average	0.310
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Jun-01	Jun-01	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Jun-01	Jun-01	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jun-01	Jun-01	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	27-Jun-01	Jun-01	0.360
				Jun-01 Average	0.323
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Jul-01	Jul-01	0.210
				Jul-01 Average	0.235
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Aug-01	Aug-01	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Aug-01	Aug-01	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Aug-01	Aug-01	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Aug-01	Aug-01	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-Aug-01	Aug-01	0.290
				Aug-01 Average	0.458
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Sep-01	Sep-01	0.230
2NPDES 113	Unit 2 STP	Chlorine, TRC	26-Sep-01	Sep-01	0.530
				Sep-01 Average	0.380
2NPDES 113	Unit 2 STP	Chlorine, TRC	16-Oct-01	Oct-01	0.270
2NPDES 113	Unit 2 STP	Chlorine, TRC	30-Oct-01	Oct-01	0.600
				Oct-01 Average	0.435
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Nov-01	Nov-01	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Nov-01	Nov-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Nov-01	Nov-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Nov-01	Nov-01	0.130
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Nov-01	Nov-01	0.370
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Nov-01	Nov-01	0.450
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Nov-01	Nov-01	0.630
				Nov-01 Average	0.307
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Dec-01	Dec-01	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Dec-01	Dec-01	0.120
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Dec-01	Dec-01	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Dec-01	Dec-01	0.130
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Dec-01	Dec-01	0.260
				Dec-01 Average	0.310

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLER POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Jan-02	Jan-02	0.070
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Jan-02	Jan-02	0.070
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Jan-02	Jan-02	0.060
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Jan-02	Jan-02	0.080
				Jan-02 Average	0.057
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Feb-02	Feb-02	0.080
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Feb-02	Feb-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.050
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.080
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Feb-02	Feb-02	0.020
				Feb-02 Average	0.062
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Mar-02	Mar-02	0.200
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Mar-02	Mar-02	0.060
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Mar-02	Mar-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Mar-02	Mar-02	0.050
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Mar-02	Mar-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Mar-02	Mar-02	0.090
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Mar-02	Mar-02	0.220
				Mar-02 Average	0.134
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Apr-02	Apr-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Apr-02	Apr-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Apr-02	Apr-02	0.160
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Apr-02	Apr-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Apr-02	Apr-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Apr-02	Apr-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Apr-02	Apr-02	0.150
				Apr-02 Average	0.164
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-May-02	May-02	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-May-02	May-02	0.240
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-May-02	May-02	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-02	May-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-May-02	May-02	0.100
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-May-02	May-02	0.180
				May-02 Average	0.163
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Jun-02	Jun-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Jun-02	Jun-02	0.320
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jun-02	Jun-02	0.220
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jun-02	Jun-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Jun-02	Jun-02	0.400
				Jun-02 Average	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jul-02	Jul-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Jul-02	Jul-02	0.230
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jul-02	Jul-02	0.110
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Jul-02	Jul-02	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-Jul-02	Jul-02	0.300

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Jul-02	Jul-02	0.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Jul-02	Jul-02	0.140
				Jul-02 Average	0.303
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Aug-02	Aug-02	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Aug-02	Aug-02	0.050
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Aug-02	Aug-02	0.230
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Aug-02	Aug-02	0.280
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Aug-02	Aug-02	0.160
				Aug-02 Average	0.208
2NPDES 113	Unit 2 STP	Chlorine, TRC	02-Sep-02	Sep-02	0.340
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Sep-02	Sep-02	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Sep-02	Sep-02	0.560
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Sep-02	Sep-02	0.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Sep-02	Sep-02	0.520
2NPDES 113	Unit 2 STP	Chlorine, TRC	30-Sep-02	Sep-02	0.550
				Sep-02 Average	0.470
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Oct-02	Oct-02	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Oct-02	Oct-02	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Oct-02	Oct-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Oct-02	Oct-02	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Oct-02	Oct-02	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Oct-02	Oct-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Oct-02	Oct-02	0.600
				Oct-02 Average	0.356
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Nov-02	Nov-02	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Nov-02	Nov-02	0.110
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Nov-02	Nov-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	15-Nov-02	Nov-02	0.050
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Nov-02	Nov-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Nov-02	Nov-02	0.170
				Nov-02 Average	0.200
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Dec-02	Dec-02	0.440
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Dec-02	Dec-02	0.280
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-02	Dec-02	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Dec-02	Dec-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Dec-02	Dec-02	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Dec-02	Dec-02	0.500
				Dec-02 Average	0.367
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jan-03	Jan-03	0.400
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Jan-03	Jan-03	0.500
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Jan-03	Jan-03	0.520
				Jan-03 Average	0.352
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Feb-03	Feb-03	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Feb-03	Feb-03	0.820

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Feb-03	Feb-03	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Feb-03	Feb-03	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Feb-03	Feb-03	0.360
				Feb-03 Average	0.476
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Mar-03	Mar-03	0.180
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Mar-03	Mar-03	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Mar-03	Mar-03	0.840
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.120
				Mar-03 Average	0.724
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Apr-03	Apr-03	0.490
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Apr-03	Apr-03	0.370
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.270
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.270
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Apr-03	Apr-03	0.110
				Apr-03 Average	0.302
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-May-03	May-03	0.530
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-May-03	May-03	0.240
				May-03 Average	0.385
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Jun-03	Jun-03	0.090
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.290
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jun-03	Jun-03	0.010
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Jun-03	Jun-03	0.250
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Jun-03	Jun-03	0.270
				Jun-03 Average	0.195
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jul-03	Jul-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Jul-03	Jul-03	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jul-03	Jul-03	0.420
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Jul-03	Jul-03	0.260
				Jul-03 Average	0.330
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Aug-03	Aug-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Aug-03	Aug-03	0.120
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Aug-03	Aug-03	0.120
				Aug-03 Average	0.167
				Grand Average	0.463

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
Maximum Daily TRC					
NPDES 203	Unit 1 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.320
				Dec-99 Maximum	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.560

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.430
				Jan-00 Maximum	0.560
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	29-Feb-00	Feb-00	0.600
				Feb-00 Maximum	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.700
NPDES 203	Unit 1 STP	Chlorine, TRC	28-Mar-00	Mar-00	0.600
				Mar-00 Maximum	0.700
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.800
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Apr-00	Apr-00	0.950
				Apr-00 Maximum	0.950
NPDES 203	Unit 1 STP	Chlorine, TRC	02-May-00	May-00	0.510
NPDES 203	Unit 1 STP	Chlorine, TRC	09-May-00	May-00	0.550
				May-00 Maximum	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Jun-00	Jun-00	0.710
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Jun-00	Jun-00	0.560
				Jun-00 Maximum	0.710
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-00	Jul-00	0.450
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jul-00	Jul-00	0.600
				Jul-00 Maximum	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Aug-00	Aug-00	0.700
NPDES 203	Unit 1 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.600
				Aug-00 Maximum	0.700
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	04-Sep-00	Sep-00	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Sep-00	Sep-00	1.000
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Sep-00	Sep-00	0.350
NPDES 203	Unit 1 STP	Chlorine, TRC	27-Sep-00	Sep-00	2.200
				Sep-00 Maximum	2.200
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Oct-00	Oct-00	0.150
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Oct-00	Oct-00	0.550
				Oct-00 Maximum	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Nov-00	Nov-00	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.320
				Nov-00 Maximum	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Dec-00	Dec-00	0.960
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.770
				Dec-00 Maximum	0.960
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jan-01	Jan-01	0.470
NPDES 203	Unit 1 STP	Chlorine, TRC	23-Jan-01	Jan-01	0.560
				Jan-01 Maximum	0.560

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Feb-01	Feb-01	0.410
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Feb-01	Feb-01	0.670
				Feb-01 Maximum	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Mar-01	Mar-01	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	20-Mar-01	Mar-01	0.340
				Mar-01 Maximum	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Apr-01	Apr-01	0.750
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Apr-01	Apr-01	0.670
NPDES 203	Unit 1 STP	Chlorine, TRC	17-Apr-01	Apr-01	0.300
				Apr-01 Maximum	0.750
NPDES 203	Unit 1 STP	Chlorine, TRC	22-May-01	May-01	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	29-May-01	May-01	0.290
				May-01 Maximum	0.290
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Jun-01	Jun-01	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	27-Jun-01	Jun-01	0.080
				Jun-01 Maximum	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.140
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.140
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Jul-01	Jul-01	0.110
				Jul-01 Maximum	0.140
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Aug-01	Aug-01	0.800
NPDES 203	Unit 1 STP	Chlorine, TRC	29-Aug-01	Aug-01	0.170
				Aug-01 Maximum	0.800
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Sep-01	Sep-01	0.070
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Sep-01	Sep-01	0.050
				Sep-01 Maximum	0.070
NPDES 203	Unit 1 STP	Chlorine, TRC	16-Oct-01	Oct-01	0.110
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Oct-01	Oct-01	0.450
				Oct-01 Maximum	0.450
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	08-Nov-01	Nov-01	0.100
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Nov-01	Nov-01	1.130
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.480
				Nov-01 Maximum	1.130
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Dec-01	Dec-01	0.350
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.520
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	31-Dec-01	Dec-01	0.130
				Dec-01 Maximum	0.520
NPDES 203	Unit 1 STP	Chlorine, TRC	10-Jan-02	Jan-02	0.500
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.120
				Jan-02 Maximum	0.500
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Feb-02	Feb-02	0.050

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	07-Feb-02	Feb-02	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.060
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	23-Feb-02	Feb-02	0.160
				Feb-02 Maximum	0.160
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	02-Mar-02	Mar-02	0.080
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Mar-02	Mar-02	0.490
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	07-Mar-02	Mar-02	0.120
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	16-Mar-02	Mar-02	0.060
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Mar-02	Mar-02	0.280
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	27-Mar-02	Mar-02	0.160
				Mar-02 Maximum	0.490
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Apr-02	Apr-02	0.070
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	04-Apr-02	Apr-02	0.180
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	12-Apr-02	Apr-02	0.250
NPDES 203	Unit 1 STP	Chlorine, TRC	18-Apr-02	Apr-02	0.250
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	27-Apr-02	Apr-02	0.240
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Apr-02	Apr-02	0.200
				Apr-02 Maximum	0.250
NPDES 203	Unit 1 STP	Chlorine, TRC	10-May-02	May-02	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	12-May-02	May-02	0.480
				May-02 Maximum	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Jun-02	Jun-02	0.530
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jun-02	Jun-02	0.550
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Jun-02	Jun-02	0.220
				Jun-02 Maximum	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jul-02	Jul-02	0.320
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	06-Jul-02	Jul-02	0.540
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	13-Jul-02	Jul-02	0.460
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	15-Jul-02	Jul-02	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Jul-02	Jul-02	0.280
				Jul-02 Maximum	0.600
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Aug-02	Aug-02	0.540
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Aug-02	Aug-02	0.110
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	29-Aug-02	Aug-02	1.180
				Aug-02 Maximum	1.180
NPDES 203	Unit 1 STP	Chlorine, TRC	02-Sep-02	Sep-02	2.480
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Sep-02	Sep-02	0.550
NPDES 203	Unit 1 STP	Chlorine, TRC	23-Sep-02	Sep-02	0.780
NPDES 203	Unit 1 STP	Chlorine, TRC	30-Sep-02	Sep-02	1.080
				Sep-02 Maximum	2.480
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Oct-02	Oct-02	0.620
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Oct-02	Oct-02	0.360
				Oct-02 Average	0.620
NPDES 203	Unit 1 STP	Chlorine, TRC	12-Nov-02	Nov-02	0.130

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
NPDES 203	Unit 1 STP	Chlorine, TRC	15-Nov-02	Nov-02	0.030
				Nov-02 Maximum	0.130
NPDES 203	Unit 1 STP	Chlorine, TRC	05-Dec-02	Dec-02	0.070
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	10-Dec-02	Dec-02	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Dec-02	Dec-02	0.180
				Dec-02 Maximum	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jan-03	Jan-03	0.180
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.150
				Jan-03 Maximum	0.180
NPDES 203	Unit 1 STP	Chlorine, TRC	03-Feb-03	Feb-03	0.380
NPDES 203	Unit 1 STP	Chlorine, TRC	13-Feb-03	Feb-03	0.300
				Feb-03 Maximum	0.380
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Mar-03	Mar-03	0.360
NPDES 203	Unit 1 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.220
				Mar-03 Maximum	1.220
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Apr-03	Apr-03	0.520
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Apr-03	Apr-03	0.030
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	15-Apr-03	Apr-03	0.060
NPDES 203	Unit 1 STP	Chlorine, TRC	16-Apr-03	Apr-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	16-Apr-03	Apr-03	0.040
NPDES 203	Unit 1 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.440
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.440
				Apr-03 Maximum	0.520
NPDES 203	Unit 1 STP	Chlorine, TRC	05-May-03	May-03	0.290
NPDES 203	Unit 1 STP	Chlorine, TRC	22-May-03	May-03	2.070
				May-03 Maximum	2.070
NPDES 203	Unit 1 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.110
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.110
NPDES 203	Unit 1 STP	Chlorine, TRC	06-Jun-03	Jun-03	2.900
NPDES 203	Unit 1 STP	Chlorine, TRC	08-Jun-03	Jun-03	0.440
NPDES 203	Unit 1 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.040
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	30-Jun-03	Jun-03	0.240
				Jun-03 Maximum	2.900
NPDES 203	Unit 1 STP	Chlorine, TRC	01-Jul-03	Jul-03	0.080
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	10-Jul-03	Jul-03	0.380
NPDES 203	Unit 1 STP	Chlorine, TRC	14-Jul-03	Jul-03	0.600
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	17-Jul-03	Jul-03	0.620
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	22-Jul-03	Jul-03	0.540
				Jul-03 Maximum	0.620
STP EFFLUENT CL2 TANK	Unit 1 STP	Chlorine, TRC	01-Aug-03	Aug-03	0.340
NPDES 203	Unit 1 STP	Chlorine, TRC	04-Aug-03	Aug-03	0.200
NPDES 203	Unit 1 STP	Chlorine, TRC	11-Aug-03	Aug-03	0.490
NPDES 203	Unit 1 STP	Chlorine, TRC	19-Aug-03	Aug-03	0.530

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
				Aug-03 Maximum	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Dec-99	Dec-99	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Dec-99	Dec-99	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Dec-99	Dec-99	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Dec-99	Dec-99	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Dec-99	Dec-99	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.480
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Dec-99	Dec-99	0.480
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Dec-99	Dec-99	0.640
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Dec-99	Dec-99	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Dec-99	Dec-99	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Dec-99	Dec-99	0.820
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Dec-99	Dec-99	0.910
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Dec-99	Dec-99	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Dec-99	Dec-99	0.770
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Dec-99	Dec-99	0.700
				Dec-99 Maximum	0.910
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Jan-00	Jan-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Jan-00	Jan-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jan-00	Jan-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Jan-00	Jan-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jan-00	Jan-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Jan-00	Jan-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jan-00	Jan-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Jan-00	Jan-00	0.560
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Jan-00	Jan-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Jan-00	Jan-00	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Jan-00	Jan-00	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Jan-00	Jan-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jan-00	Jan-00	0.170
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Jan-00	Jan-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Jan-00	Jan-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Jan-00	Jan-00	0.530
				Jan-00 Maximum	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Feb-00	Feb-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Feb-00	Feb-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Feb-00	Feb-00	0.560

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Feb-00	Feb-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Feb-00	Feb-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Feb-00	Feb-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Feb-00	Feb-00	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Feb-00	Feb-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Feb-00	Feb-00	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Feb-00	Feb-00	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Feb-00	Feb-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Feb-00	Feb-00	0.500
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Feb-00	Feb-00	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Feb-00	Feb-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Feb-00	Feb-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-Feb-00	Feb-00	0.650
				Feb-00 Maximum	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Mar-00	Mar-00	0.620
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Mar-00	Mar-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Mar-00	Mar-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Mar-00	Mar-00	0.850
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Mar-00	Mar-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Mar-00	Mar-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Mar-00	Mar-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Mar-00	Mar-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Mar-00	Mar-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	28-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Mar-00	Mar-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Mar-00	Mar-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Mar-00	Mar-00	0.800
				Mar-00 Maximum	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Apr-00	Apr-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Apr-00	Apr-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Apr-00	Apr-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Apr-00	Apr-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Apr-00	Apr-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Apr-00	Apr-00	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Apr-00	Apr-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Apr-00	Apr-00	0.910

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLER POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Apr-00	Apr-00	0.760
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Apr-00	Apr-00	0.500
				Apr-00 Maximum	0.910
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-May-00	May-00	0.840
2NPDES 113	Unit 2 STP	Chlorine, TRC	02-May-00	May-00	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-May-00	May-00	0.780
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-May-00	May-00	0.540
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-May-00	May-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-00	May-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-00	May-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-May-00	May-00	0.570
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-May-00	May-00	0.550
				May-00 Maximum	0.840
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jun-00	Jun-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Jun-00	Jun-00	0.820
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Jun-00	Jun-00	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Jun-00	Jun-00	0.950
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Jun-00	Jun-00	0.810
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jun-00	Jun-00	0.800
				Jun-00 Maximum	0.950
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	05-Jul-00	Jul-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jul-00	Jul-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jul-00	Jul-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Jul-00	Jul-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Jul-00	Jul-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	31-Jul-00	Jul-00	0.600
				Jul-00 Maximum	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Aug-00	Aug-00	0.700
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Aug-00	Aug-00	0.800
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Aug-00	Aug-00	0.700
2NPDES 113	Unit 2 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Aug-00	Aug-00	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Aug-00	Aug-00	0.500
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Aug-00	Aug-00	0.600
				Aug-00 Maximum	0.900
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Sep-00	Sep-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Sep-00	Sep-00	1.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Sep-00	Sep-00	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Sep-00	Sep-00	0.170
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Sep-00	Sep-00	0.590
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Sep-00	Sep-00	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	27-Sep-00	Sep-00	4.300
				Sep-00 Maximum	4.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Oct-00	Oct-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Oct-00	Oct-00	0.380
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Oct-00	Oct-00	0.210
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Oct-00	Oct-00	0.690

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Oct-00	Oct-00	0.650
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Oct-00	Oct-00	0.370
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Oct-00	Oct-00	0.120
				Oct-00 Maximum	0.690
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Nov-00	Nov-00	0.160
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Nov-00	Nov-00	0.540
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.440
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Nov-00	Nov-00	0.130
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Nov-00	Nov-00	0.670
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Nov-00	Nov-00	0.450
				Nov-00 Maximum	0.670
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Dec-00	Dec-00	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Dec-00	Dec-00	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Dec-00	Dec-00	0.750
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.650
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Dec-00	Dec-00	0.650
				Dec-00 Maximum	0.750
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jan-01	Jan-01	0.860
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Jan-01	Jan-01	0.860
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Jan-01	Jan-01	0.400
2NPDES 113	Unit 2 STP	Chlorine, TRC	23-Jan-01	Jan-01	0.840
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Jan-01	Jan-01	0.560
				Jan-01 Maximum	0.860
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Feb-01	Feb-01	0.470
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Feb-01	Feb-01	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Feb-01	Feb-01	0.390
				Feb-01 Maximum	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Mar-01	Mar-01	0.290
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Mar-01	Mar-01	0.100
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Mar-01	Mar-01	0.230
2NPDES 113	Unit 2 STP	Chlorine, TRC	20-Mar-01	Mar-01	0.150
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Mar-01	Mar-01	0.140
				Mar-01 Maximum	0.290
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Apr-01	Apr-01	0.650
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Apr-01	Apr-01	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Apr-01	Apr-01	0.710
2NPDES 113	Unit 2 STP	Chlorine, TRC	17-Apr-01	Apr-01	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Apr-01	Apr-01	0.530
				Apr-01 Maximum	0.710
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-May-01	May-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-May-01	May-01	0.180
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-May-01	May-01	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-May-01	May-01	0.240
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-May-01	May-01	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-May-01	May-01	0.520

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
				May-01 Maximum	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Jun-01	Jun-01	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Jun-01	Jun-01	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jun-01	Jun-01	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	27-Jun-01	Jun-01	0.360
				Jun-01 Maximum	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Jul-01	Jul-01	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Jul-01	Jul-01	0.210
				Jul-01 Maximum	0.260
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Aug-01	Aug-01	0.700
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Aug-01	Aug-01	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Aug-01	Aug-01	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Aug-01	Aug-01	0.600
2NPDES 113	Unit 2 STP	Chlorine, TRC	29-Aug-01	Aug-01	0.290
				Aug-01 Maximum	0.700
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Sep-01	Sep-01	0.230
2NPDES 113	Unit 2 STP	Chlorine, TRC	26-Sep-01	Sep-01	0.530
				Sep-01 Maximum	0.530
2NPDES 113	Unit 2 STP	Chlorine, TRC	16-Oct-01	Oct-01	0.270
2NPDES 113	Unit 2 STP	Chlorine, TRC	30-Oct-01	Oct-01	0.600
				Oct-01 Maximum	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Nov-01	Nov-01	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Nov-01	Nov-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Nov-01	Nov-01	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Nov-01	Nov-01	0.130
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Nov-01	Nov-01	0.370
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	19-Nov-01	Nov-01	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	26-Nov-01	Nov-01	0.450
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Nov-01	Nov-01	0.630
				Nov-01 Maximum	0.630
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	03-Dec-01	Dec-01	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.510
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Dec-01	Dec-01	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Dec-01	Dec-01	0.120
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Dec-01	Dec-01	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Dec-01	Dec-01	0.130
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-Dec-01	Dec-01	0.260
				Dec-01 Maximum	0.510
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Jan-02	Jan-02	0.070
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-Jan-02	Jan-02	0.070
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Jan-02	Jan-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Jan-02	Jan-02	0.060
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	28-Jan-02	Jan-02	0.080

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
				Jan-02 Maximum	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Feb-02	Feb-02	0.080
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Feb-02	Feb-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.050
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	11-Feb-02	Feb-02	0.080
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Feb-02	Feb-02	0.020
				Feb-02 Maximum	0.080
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Mar-02	Mar-02	0.200
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Mar-02	Mar-02	0.060
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	07-Mar-02	Mar-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Mar-02	Mar-02	0.050
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Mar-02	Mar-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Mar-02	Mar-02	0.090
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Mar-02	Mar-02	0.220
				Mar-02 Maximum	0.220
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Apr-02	Apr-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Apr-02	Apr-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Apr-02	Apr-02	0.160
2NPDES 113	Unit 2 STP	Chlorine, TRC	18-Apr-02	Apr-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	20-Apr-02	Apr-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	27-Apr-02	Apr-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Apr-02	Apr-02	0.150
				Apr-02 Maximum	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-May-02	May-02	0.100
2NPDES 113	Unit 2 STP	Chlorine, TRC	10-May-02	May-02	0.240
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-May-02	May-02	0.160
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-May-02	May-02	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-May-02	May-02	0.100
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	31-May-02	May-02	0.180
				May-02 Maximum	0.240
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Jun-02	Jun-02	0.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Jun-02	Jun-02	0.320
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jun-02	Jun-02	0.220
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jun-02	Jun-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Jun-02	Jun-02	0.400
				Jun-02 Maximum	0.400
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jul-02	Jul-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Jul-02	Jul-02	0.230
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Jul-02	Jul-02	0.110
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	16-Jul-02	Jul-02	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-Jul-02	Jul-02	0.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	23-Jul-02	Jul-02	0.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Jul-02	Jul-02	0.140
				Jul-02 Maximum	0.800
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Aug-02	Aug-02	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Aug-02	Aug-02	0.050

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLEPOINT	DESCRIPTION	ANALYSIS	SAMPLEDATE	Month	RESULT
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Aug-02	Aug-02	0.230
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Aug-02	Aug-02	0.280
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Aug-02	Aug-02	0.160
				Aug-02 Maximum	0.320
2NPDES 113	Unit 2 STP	Chlorine, TRC	02-Sep-02	Sep-02	0.340
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Sep-02	Sep-02	0.550
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Sep-02	Sep-02	0.560
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Sep-02	Sep-02	0.300
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Sep-02	Sep-02	0.520
2NPDES 113	Unit 2 STP	Chlorine, TRC	30-Sep-02	Sep-02	0.550
				Sep-02 Maximum	0.560
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Oct-02	Oct-02	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Oct-02	Oct-02	0.520
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	09-Oct-02	Oct-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Oct-02	Oct-02	0.320
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Oct-02	Oct-02	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Oct-02	Oct-02	0.030
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Oct-02	Oct-02	0.600
				Oct-02 Maximum	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	04-Nov-02	Nov-02	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	12-Nov-02	Nov-02	0.110
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	14-Nov-02	Nov-02	0.080
2NPDES 113	Unit 2 STP	Chlorine, TRC	15-Nov-02	Nov-02	0.050
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Nov-02	Nov-02	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	29-Nov-02	Nov-02	0.170
				Nov-02 Maximum	0.550
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-Dec-02	Dec-02	0.440
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	06-Dec-02	Dec-02	0.280
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	10-Dec-02	Dec-02	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	19-Dec-02	Dec-02	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	21-Dec-02	Dec-02	0.580
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Dec-02	Dec-02	0.500
				Dec-02 Average	0.580
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jan-03	Jan-03	0.400
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Jan-03	Jan-03	0.500
2NPDES 113	Unit 2 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.200
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Jan-03	Jan-03	0.140
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	15-Jan-03	Jan-03	0.520
				Jan-03 Maximum	0.520
2NPDES 113	Unit 2 STP	Chlorine, TRC	03-Feb-03	Feb-03	0.240
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	12-Feb-03	Feb-03	0.820
2NPDES 113	Unit 2 STP	Chlorine, TRC	13-Feb-03	Feb-03	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Feb-03	Feb-03	0.600
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Feb-03	Feb-03	0.360
				Feb-03 Maximum	0.820
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Mar-03	Mar-03	0.180

Unit 1 and Unit 2 Additional Monitoring Results

SAMPLE POINT	DESCRIPTION	ANALYSIS	SAMPLE DATE	Month	RESULT
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	08-Mar-03	Mar-03	0.360
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	13-Mar-03	Mar-03	0.840
2NPDES 113	Unit 2 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.120
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	24-Mar-03	Mar-03	1.120
				Mar-03 Maximum	1.120
2NPDES 113	Unit 2 STP	Chlorine, TRC	07-Apr-03	Apr-03	0.490
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Apr-03	Apr-03	0.370
2NPDES 113	Unit 2 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.270
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Apr-03	Apr-03	0.270
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Apr-03	Apr-03	0.110
				Apr-03 Maximum	0.490
2NPDES 113	Unit 2 STP	Chlorine, TRC	05-May-03	May-03	0.530
2NPDES 113	Unit 2 STP	Chlorine, TRC	22-May-03	May-03	0.240
				May-03 Maximum	0.530
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	02-Jun-03	Jun-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	06-Jun-03	Jun-03	0.090
2NPDES 113	Unit 2 STP	Chlorine, TRC	09-Jun-03	Jun-03	0.290
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	18-Jun-03	Jun-03	0.010
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	25-Jun-03	Jun-03	0.250
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	30-Jun-03	Jun-03	0.270
				Jun-03 Maximum	0.290
2NPDES 113	Unit 2 STP	Chlorine, TRC	01-Jul-03	Jul-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	14-Jul-03	Jul-03	0.380
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	17-Jul-03	Jul-03	0.420
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	22-Jul-03	Jul-03	0.260
				Jul-03 Maximum	0.420
2STP EFFLUENT CL2 TANK	Unit 2 STP	Chlorine, TRC	01-Aug-03	Aug-03	0.260
2NPDES 113	Unit 2 STP	Chlorine, TRC	04-Aug-03	Aug-03	0.120
2NPDES 113	Unit 2 STP	Chlorine, TRC	11-Aug-03	Aug-03	0.120
				Aug-03 Maximum	0.260
				Grand Maximum	4.300