

5.0 ADMINISTRATIVE CONTROLS

5.3 Plant Staff Qualifications

- 5.3.1 Each member of the plant staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions except for the education and experience eligibility requirements for operator license applicants, and changes thereto, shall be those previously reviewed and approved by the NRC, specifically those referenced in NRC Safety Evaluation dated October 24, 2003.
- 5.3.2 The radiation safety manager shall meet the qualifications of a Radiation Protection Manager as defined in Regulatory Guide 1.8, September 1975. For the purpose of this section, "Equivalent," as utilized in Regulatory Guide 1.8 for the bachelor's degree requirement, may be met with four years of any one or combination of the following: (a) Formal schooling in science or engineering, or (b) operational or technical experience and training in nuclear power.
- 5.3.3 The individual, required by Specification 5.2.2g, assigned to provide advisory technical support to the plant operations shift crew, shall meet the qualifications specified by the Commission Policy Statement on Engineering Expertise on Shift (Published in Federal Register 50 FR 43621, October 28, 1985).
- 5.3.4 The plant staff who perform reviews which ensure compliance with 10 CFR 50.59 shall meet or exceed the minimum qualifications of ANS 3.1-1987, Section 4.7.1 and 4.7.2. A Senior Reactor Operator license or certification shall be considered equivalent to a bachelors degree for the purpose of this specification.
-