

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Kevin J. Moles
Manager Regulatory Affairs

NOV 11 2003

RA 03-0138


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Docket No. 50-482: October 2003 Monthly Operating Report

Gentlemen:

Attached to this letter is the October 2003, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports." This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have any questions regarding this report, please contact me at (620) 364-4126, or Ms. Jennifer Yunk at (620) 364-4272.

Very truly yours,



-Kevin J. Moles

KJM/rlg

Attachment

cc: J. N. Donohew (NRC), w/a
D. N. Graves (NRC), w/a
B. S. Mallett (NRC), w/a
Senior Resident Inspector (NRC), w/a

JE24

OPERATING DATA REPORT
Report Number: 224

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: November 11, 2003
COMPLETED BY: J. L. Yunk
TELEPHONE: (620) 364-4272

REPORT MONTH: October 2003

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1167

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	408.0	6,903.3	137,039.1
4.	Number of Hours Generator On-Line:	408.0	6,890.7	135,836.5
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	463,379.0	8,095,265.0	154,173,969.0

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: November 11, 2003
COMPLETED BY: J. L. Yunk
TELEPHONE: (620) 364-4272

No.	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
03-03	10/18/2003	S	337.00	C	1	Refueling Outage XIII began on 11/18/2003 @ 00:00 midnight.

SUMMARY: The unit operated in Mode 1 from October 1, 2003 until the beginning of refueling outage XIII at 00:00 on October 18, 2003.

(1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)
B: MAINTENANCE OR TEST
C: REFUELING
D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION
F: ADMINISTRATIVE
G: OPERATIONAL ERROR (EXPLAIN)
H: OTHER (EXPLAIN)

(2) METHOD: 1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUATION
5. OTHER

Wolf Creek Generating Station
Monthly Operating Report
October 2003
Page 2 of 2