



An Energy East Company

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001 • 585 546-2700

www.rge.com

November 10, 2003


US Nuclear Regulatory Commission  
Document Control Desk  
Attn: Robert Clark  
Project Directorate I-1  
Washington, DC 20555

Subject: Monthly Report for October 2003  
Operating Status Information  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Clark:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of October 2003.

Very truly yours,

  
Joseph A. Widay  
Plant Manager

xc: U.S. Nuclear Regulatory Commission  
Mr. Robert Clark (Mail Stop O-8E9)  
Project Directorate I-1  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

IE24

# OPERATING DATA REPORT

-1-

50-244

November 10, 2003

COMPLETED BY:

*John V. Walden*

John V. Walden

TELEPHONE (585) 771-3588

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: October, 2003
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

Notes:

	This Month	Yr.-to-Date	Cumulative*
5. Number of hours Reactor Was Critical	<u>412.5</u>	<u>6517.3</u>	<u>245534.2</u>
6. Hours Generator On-line	<u>378.5</u>	<u>6462.6</u>	<u>242321.7</u>
7. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5</u> *
8. Net Electrical Energy Generated (MWH)	<u>168563.7</u>	<u>3142171.0</u>	<u>110471080.0</u>

\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244  
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT  
DATE: November 10, 2003  
COMPLETED BY: John V. Walden  
TELEPHONE: (585) 771-3588

### UNIT SHUTDOWN

REPORTING PERIOD: October 2003  
(Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON <sup>(1)</sup>	METHOD OF SHUTTING DOWN <sup>(2)</sup>	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
4	030915	S	366.5	C	1	Refueling and maintenance outage
5	031015	F	13.0	H	2	Loss of offsite circuit reactor trip

SUMMARY: The unit began the month of October in a refueling shutdown which started on September 15, 2003. Following the completion of refueling and reactor head replacement, the reactor was made critical on October 14, 2003 at 0729. High winds on October 15, 2003 caused a branch to lay across phases of offsite circuit 751. The circuit opened and caused the loss of one reactor coolant pump. Emergency procedures directed the manual scram of the reactor at 1025 on October 15, 2003. The reactor was made critical again at 2325 later the same day. The unit was placed on-line at 0630 on October 16, 2003. Full power was reached on October 20, 2003 and remained there through the end of the month.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)