

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.7 Inverters-Operating

LCO 3.8.7 Four instrument bus inverters shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One instrument bus inverter inoperable.	A.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.9, "Distribution Systems-Operating" with any instrument bus de-energized. ----- Restore inverter to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	36 hours

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.7 Inverters-Operating

LCO 3.8.7 Four instrument bus inverters shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One instrument bus inverter inoperable.	A.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.9, "Distribution Systems-Operating" with any instrument bus de-energized. ----- Restore inverter to OPERABLE status.	7 days
	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5.	6 hours  36 hours
B. Required Action and associated Completion Time not met.		