

November 21, 2003

Mr. James F. Mallay  
Director, Regulatory Affairs  
Framatome ANP  
3815 Old Forest Road  
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR FRAMATOME ANP TOPICAL REPORT  
BAW-10231P, "COPERNIC FUEL ROD DESIGN CODE" CHAPTER 13, MOX  
APPLICATIONS (TAC NO. MB7547)

Dear Mr. Mallay:

Enclosed for Framatome's review and comment is a copy of the staff's draft safety evaluation (SE) for Topical Report (TR) BAW-10231P, "COPERNIC Fuel Rod Design Code" Chapter 13, MOX Applications.

Pursuant to 10 CFR 2.790, we have determined that the enclosed draft SE does not contain proprietary information. However, we will delay placing the draft SE in the public document room for a period of ten working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects only. If you believe that any information in the enclosure is proprietary, please identify such information line by line and define the basis pursuant to the criteria of 10 CFR 2.790. Following your agreement that the draft SE is non-proprietary, we will place it in the public document room while you continue your review for factual errors or clarity concerns. Please identify any such errors or concerns within 20 working days of the date of this letter.

In the event of any comments or questions, please contact Drew Holland at (301) 415-1436.

Sincerely,

**/RA**

Stephen/ Dembek, Chief, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 728

Enclosure: Draft Safety Evaluation

November 21, 2003

Mr. James F. Mallay  
Director, Regulatory Affairs  
Framatome ANP  
3815 Old Forest Road  
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR FRAMATOME ANP TOPICAL REPORT  
BAW-10231P, "COPERNIC FUEL ROD DESIGN CODE" CHAPTER 13, MOX  
APPLICATIONS (TAC NO. MB7547)

Dear Mr. Mallay:

Enclosed for Framatome's review and comment is a copy of the staff's draft safety evaluation (SE) for Topical Report (TR) BAW-10231P, "COPERNIC Fuel Rod Design Code" Chapter 13, MOX Applications.

Pursuant to 10 CFR 2.790, we have determined that the enclosed draft SE does not contain proprietary information. However, we will delay placing the draft SE in the public document room for a period of ten working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects only. If you believe that any information in the enclosure is proprietary, please identify such information line by line and define the basis pursuant to the criteria of 10 CFR 2.790. Following your agreement that the draft SE is non-proprietary, we will place it in the public document room while you continue your review for factual errors or clarity concerns. Please identify any such errors or concerns within 20 working days of the date of this letter.

In the event of any comments or questions, please contact Drew Holland at (301) 415-1436.

Sincerely,

**/RA/**

Stephen Dembek, Chief, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 728

Enclosure: Draft Safety Evaluation

**DISTRIBUTION:**

**PUBLIC (No DPC folder for 10 working days)**

PDIV-2 Reading  
RidsNrrDlpmPdiv (HBerkow)  
RidsNrrPMDHolland  
RidsNrrLAEPeyton  
JWermiel  
FAkstulewicz  
SWu  
RidsOgcRp  
RidsAcraAcnwMailCenter

**ACCESSION NO: ML033290099**

**NRR-106**

OFFICE	PDIV-2/PM	PDIV-2/LA	SRXB	PDIV-2/SC
NAME	DHolland	EPeyton	FAkstulewicz	SDembek
DATE	11/12/03	11/10/03	11/14/03	11/20/03

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML033290099.wpd

OFFICIAL RECORD COPY



DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

BAW-10231P, "COPERNIC FUEL ROD DESIGN COMPUTER CODE"

CHAPTER 13 - MOX APPLICATIONS

FRAMATOME ANP

PROJECT NO. 728

1.0 INTRODUCTION

Framatome Cogema Fuels (now known as Framatome ANP [FANP]) submitted to the NRC staff Chapter 13 (Reference 1) of Topical Report (TR) BAW-10231P, entitled "COPERNIC Fuel Rod Design Computer Code," for review and approval. Chapter 13 describes a design and analysis methodology for mixed oxide (MOX) fuel rod performance. MOX fuel pellets have a mixture of uranium dioxide ( $\text{UO}_2$ ) and plutonium dioxide ( $\text{PuO}_2$ ). Currently, there are two types of  $\text{PuO}_2$  in MOX fuel designs used in commercial nuclear reactors: reactor-grade  $\text{PuO}_2$  fuel and weapons-grade (WG)  $\text{PuO}_2$  fuel. FANP intended to use the WG  $\text{PuO}_2$  fuel for MOX fuel designs.

The staff has previously approved the COPERNIC code for  $\text{UO}_2$  licensing applications (References 2 and 3) with advanced cladding material, M5, to a peak rod average burnup of 62 GWd/MTU. Although Chapter 13 is an extended application of the COPERNIC code, detailed MOX fuel designs including irradiation experiences are described in other FANP TRs such as BAW-10238(P), Revision 1, entitled "MOX Fuel Design Report." FANP requested an approval of the COPERNIC code for MOX licensing applications to a Pu content of 6 weight percent (wt%) and a peak rod average burnup of 53 GWd/MTU. However, the staff notes that the MOX irradiated data provided by FANP and audit verifications are only up to a peak rod average burnup of 50 GWd/MTU.

As a result of the staff's review, assisted by its consultant Pacific Northwest National Laboratory (PNNL), two requests for additional information (RAIs) were sent to FANP (References 4 and 5). FANP provided responses in References 6, 7, and 8.

This review addresses those major computer models of the MOX fuel design features in the COPERNIC code that are different from the  $\text{UO}_2$  fuel design features, and the MOX fuel design licensing applications. The licensing applications include fuel melting analysis, fuel rod internal pressure, cladding strain, and stored energy for a loss-of-coolant accident (LOCA).

The staff used the NRC audit code, FRAPCON-3.2 with MOX properties (Reference 9), to evaluate the models and analytical results from the COPERNIC code. The FRAPCON-3.2 code is a modification of the  $\text{UO}_2$  version of the FRAPCON-3 code (Reference 10). The

FRAPCON-3.2 code has been verified against thermal data from irradiated MOX fuel rod segments to rod average burnup of 60 GWd/MTU. The verification process demonstrated that the FRAPCON-3.2 code provided best-estimate predictions of the thermal and fission gas release data for MOX fuel rods.

## 2.0 REGULATORY EVALUATION

The objectives of the fuel system safety review are to provide assurance that (1) the fuel system is not damaged as a result of normal operation and anticipated operational occurrences, (2) fuel system damage is never so severe as to prevent control rod insertion when it is required, (3) the number of fuel rod failures is not underestimated for postulated accidents, and (4) coolability is always maintained. The staff acceptance criteria are based on Section 4.2, "Fuel System Design," of the Standard Review Plan (SRP). These criteria include three parts: (1) design bases that describe specified acceptable fuel design limits as depicted in General Design Criterion 10 to 10 CFR Part 50, Appendix A, (2) design evaluation that demonstrates that the design bases are met, and (3) testing, inspection, and surveillance plans that show that there are adequate monitoring and surveillance of irradiated fuel. The design bases include (1) fuel system damage, (2) fuel rod failure, and (3) fuel coolability.

## 3.0 TECHNICAL EVALUATION

### 3.1 Fuel Thermal Conductivity

The COPENIC MOX fuel thermal conductivity model is similar to that used for  $\text{UO}_2$  (including the burnup dependence) with the addition of two terms, which are functions of  $\text{PuO}_2$  content and oxygen-to-metal (O/M) ratio. The staff compared the COPENIC MOX thermal conductivity model to the MOX thermal conductivity model (Reference 11) used in the FRAPCON-3.2 code. The MOX thermal conductivity model in FRAPCON-3.2 is based on the Duriez model (Reference 12) for unirradiated MOX fuel pellets (with O/M dependence) along with the burnup dependence proposed by the staff's consultant, PNNL (References 13 and 14). The comparison showed that the two models were close for the low burnup regime, and FRAPCON-3.2 had slightly higher fuel temperature predictions than COPENIC for the high burnup regime.

The comparison of the COPENIC MOX thermal conductivity model to in-reactor Halden fuel temperature data also showed a similar trend of good agreement between the two except at the high burnup regime. The COPENIC model could slightly underpredict fuel temperatures at the high burnup regime. Overall, the COPENIC model showed consistent results with the FRAPCON-3.2 code and Halden data.

Based on the overall good agreement of the temperature predictions, the staff concludes that the MOX thermal conductivity model is acceptable for the COPENIC MOX code to rod average burnup of 50 GWd/MTU.

### 3.2 Fission Gas Release

Fission gas release is important because it degrades the fuel-to-clad gap conductance and simultaneously increases fuel rod pressures. There are two fission gas release (FGR) models

in the COPENIC code: a steady-state model and a transient model. FANP has FGR data from the Halden reactor as well as its own irradiation program.

The audit code FRAPCON-3.2 uses a release model that is taken from the American Nuclear Society (ANS) Standard 5.4 (Reference 15) and a thermally-activated diffusion model proposed by Forsberg and Massih (Reference 16) with modifications to the diffusion coefficient. The FRAPCON-3.2 model also assumes that the fission gas is stored on the grain boundary until saturation, and the gas saturation level is the same for MOX and  $\text{UO}_2$  fuel. The COPENIC code adopts a similar approach.

The COPENIC code was compared to MOX FGR from steady-state power operations. The COPENIC comparisons to the data showed that the code provided a best-estimate calculation of FGR for steady-state operations. The COPENIC code assumes that the transient release model for MOX is identical to that for  $\text{UO}_2$  fuel. The transient release results were compared to power ramp data. The COPENIC code conservatively overpredicted the measured FGR on most of the power ramp data. Based on the overprediction of the majority of the data, the staff considers that the FGR models have adequate conservatism and the predictions are acceptable.

FGR has significant impact on the end-of-life (EOL) rod pressure analysis for the peak operating rods within a core. The rod pressure analysis generally limits the peak linear heat generation rates (LHGRs) at high burnup levels. The staff performed an audit calculation of an EOL rod pressure provided by FANP using best-estimate input values. This audit calculation demonstrated that the audit code predicted slightly higher rod pressures than the COPENIC code at EOL, but the differences were very small when compared to the uncertainties in the analysis.

Based on the good agreement between the two codes, the staff concludes that the fission gas release predictions are acceptable for the COPENIC MOX code to rod average burnup of 50 GWd/MTU.

### 3.3 Fuel Densification and Swelling

The fuel densification and swelling models in COPENIC are important for cladding strain, fuel melting, and LOCA analyses. FANP determined the fuel densification according to the recommendation of Regulatory Guide 1.126 (Reference 17). FANP provided data to demonstrate that the MOX fuel was similar to  $\text{UO}_2$  fuel in fuel densification and swelling performance. The COPENIC predictions also compared reasonably well with those measured from MOX fuel. A comparison of the densification and swelling models in COPENIC and FRAPCON-3.2 showed that the two models were very similar in densification kinetics.

Based on the comparison of the two codes with the densification and swelling data, the staff concludes that the fuel densification and swelling models are acceptable for the COPENIC MOX code to a rod average burnup of 50 GWd/MTU.

### 3.4 Power-to-Melt Analysis

The difference between COPENIC and FRAPCON-3.2 fuel thermal conductivity models at the high temperature regime leads to a difference in power-to-melt calculations. The staff performed an audit calculation using the FRAPCON-3.2 code. The results showed that the two codes predicted very closely at the beginning of life, but the COPENIC code predicted a slightly higher result than the FRAPCON-3.2 code for higher burnups. The staff considers that the minor difference in the power-to-melt analysis has little impact in the overall safety analyses.

Based on the conservative thermal models and the comparisons with the audit code, the staff concludes that the power-to-melt analysis is acceptable for the COPENIC MOX code to a rod average burnup of 50 GWd/MTU.

### 3.5 Fuel Rod Internal Pressure

FANP uses the COPENIC code to verify the maximum EOL rod pressure for a MOX fuel design. FANP provided an EOL fuel rod internal pressure analysis of a Mark-BW fuel design. The staff performed an audit calculation with FRAPCON-3.2 using the same input, and FRAPCON-3.2 predicted similar results as COPENIC.

Based on the similar results, the staff concludes that the fuel rod internal pressure analysis is acceptable for the COPENIC MOX code to a rod average burnup of 50 GWd/MTU.

### 3.6 Clad Strain

Section 4.2 of the SRP establishes that the 1 percent strain limit should be used for normal operation and anticipated operational occurrences. FANP provided a clad strain analysis of a Mark-BW fuel design. The staff performed an audit calculation with FRAPCON-3.2 using the same input. The results showed that FRAPCON-3.2 predicted a slightly lower threshold than COPENIC in reaching the 1 percent strain limit. The staff considers that the difference has little impact in the safety analyses because of the code conservatism and very limited irradiated strain data.

Based on the conservative mechanical models and compatible results, the staff concludes that the cladding strain analysis is acceptable for the COPENIC MOX code to a rod average burnup of 50 GWd/MTU.

### 3.7 Stored Energy

FANP uses the COPENIC MOX code to calculate initial fuel stored energy for LOCA analyses to verify that the MOX fuel design meets the requirements of Appendix K to 10 CFR Part 50. The fuel stored energy is approximately proportional to the fuel volume-average temperature.

The staff uses prediction-to-measurement comparisons at LHGR levels for LOCA stored energy calculations to estimate uncertainty including standard deviation in fuel performance codes. The uncertainty is then applied to code predictions to obtain a conservative stored energy prediction at a 95/95 tolerance level (bounding 95 percent of the measured data with a 95

percent confidence) for LOCA analyses. The staff used the FRAPCON-3.2 code to compare the results from the COPENIC code for stored energy calculations to a rod average burnup of 50 GWd/MTU.

All fuel performance codes with  $\text{UO}_2$  fuel examined by the staff including the FRAPCON code have a standard deviation equivalent to 6 to 8 percent. The 6 to 8 percent standard deviation is consistent with the standard deviation of the measured  $\text{UO}_2$  fuel rod powers. FANP demonstrated that the COPENIC code predicted best-estimate, i.e., small standard deviation, fuel centerline temperatures for the Halden MOX irradiated data. The COPENIC code has a smaller standard deviation for the MOX data than for the  $\text{UO}_2$  data. The COPENIC code predicted small standard deviation on the MOX data may be attributed to two different reasons: (1) the LHGRs of the majority of the MOX data are low resulting in low measured temperatures, and (2) the number of irradiated MOX fuel rods is much smaller than the number of irradiated  $\text{UO}_2$  fuel rods.

A comparison between predicted and measured fuel temperatures at a 95/95 tolerance level from these irradiated MOX data showed that the COPENIC code slightly underpredicted fuel temperatures. The COPENIC fuel temperature uncertainty performance is consistent with the audit code FRAPCON-3.2 behavior in that both codes slightly underpredict the data at a 95/95 tolerance level. The staff recognizes that the MOX fuel has a smaller data base than the  $\text{UO}_2$  data base. A small data base will generally result in a small uncertainty. In order to compensate for the smaller data base and the underprediction, FANP opted for a conservative approach using a large fuel uncertainty from the  $\text{UO}_2$  data base for the MOX fuel stored energy calculations (Reference 18). Based on the small data base and conservative treatment of uncertainty, the staff accepted this conservative approach to address the underprediction.

Based on the best-estimate performance and a conservative approach to the 95/95 tolerance, the staff concludes that the stored energy analysis for LOCA initial conditions is acceptable for the COPENIC MOX code to a rod average burnup of 50 GWd/MTU.

#### 4.0 CONCLUSION

The staff has reviewed the FANP MOX fuel rod performance in Chapter 13 of the COPENIC code of BAW-10231P. Based on the staff's review, as supplemented by its contractor's, PNNL, review and evaluation, the staff concludes that the COPENIC code is acceptable for MOX fuel licensing applications up to a WG Pu content of 6 wt% and a peak rod average burnup of 50 GWd/MTU. Future staff reviews involving MOX fuel designs may result in additional restrictions on the licensing applications of the COPENIC code.

#### 5.0 REFERENCES

1. Framatome Cogema Fuels. July 31, 2000. *COPENIC Fuel Rod Design Computer Code, Chapter 13 MOX Applications*. BAW-10231P, Framatome Cogema Fuels, Lynchburg, Virginia, transmitted by letter, T. A. Coleman (Framatome Cogema Fuels) to U.S. NRC Document Control Desk, "Topical Report BAW-10231P, COPENIC Fuel Rod Design Computer Code, Chapter 13 MOX Applications" dated September 16, 1999, GR00-088.doc.



2. Framatome Cogema Fuels. September 1997. *COPERNIC Fuel Rod Design Computer Code*. BAW-10231P, Framatome Cogema Fuels, Lynchburg, Virginia, transmitted by letter, T. A. Coleman (Framatome Cogema Fuels) to U.S. NRC Document Control Desk, "Topical Report BAW-10231P, COPERNIC Fuel Rod Design Computer Code," dated September 16, 1999, GR99-191.doc.
3. Framatome Cogema Fuels. *COPERNIC Fuel Rod Design Computer Code, Chapter 12 Application Methodology (United States)*. BAW-10231P, Framatome Cogema Fuels, Lynchburg, Virginia, transmitted by letter, Stewart Bailey, NRC, to T. A. Coleman, Framatome Cogema Fuels, - *COPERNIC Fuel Rod Design Computer Code, Chapter 12 Application Methodology (United States)* Topical Report BAW-10231P, December 2, 1999, GR99-234.doc.
4. Letter, Stewart Bailey (NRC) to T. A. Coleman (Framatome ANP), "Request for Additional Information - Chapter 13 of Framatome Topical Report BAW-10231P (TAC No. MA9783)," May 14, 2001.
5. Letter, Drew Holland (NRC) to James Mallay (Framatome ANP), "Request for Additional Information - BAW-10231P, Chapter 13, COPERNIC MOX Applications, Fuel Rod Design Computer Code," dated April 25, 2002.
6. Letter, James Mallay (Framatome ANP) to NRC Document Control Desk, "Partial Response to RAI," NRC:01:033, July 27, 2001.
7. Letter, James Mallay (Framatome ANP) to NRC Document Control Desk, "Partial Response to RAI on Chapter 13 of BAW-10231P," NRC:02:021, April 26, 2002.
8. Letter, James Mallay (Framatome ANP) to NRC Document Control Desk, "Partial Response to RAI on Chapter 13 of BAW-10231P," NRC:02:038, July 17, 2002.
9. Berna, G.A., C.E. Beyer, K.L. Davis and D.D. Lanning. 1997. *FRAPCON-3: A Computer Code for the Calculation of Steady-State, Thermal-Mechanical Behavior of Oxide Fuel Rods for High Burnup*. NUREG/CR-6534 (PNNL-11513) Vol. 2. U.S. Nuclear Regulatory Commission, Washington, D.C.
10. Lanning, D.D., C.E. Beyer and C.L. Painter. 1997. *FRAPCON-3: Modifications to Fuel Rod Material Properties and Performance Models for High-Burnup Applications*. NUREG/CR-6534 (PNNL-11513) Vol. 1. U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001.
11. Lanning, D. D. and C. E. Beyer. 2002. "Proposed FRAPCON-3 MOX Fuel Thermal Conductivity Model Compare to Halden Fuel Temperature Data," *Presented at Enlarged Halden Program Meeting, September 8-13, 2002*.
12. Duriez, C., J.P. Allesandri, T. Gervais, and Y. Philipponneau. 2000. "Thermal Conductivity of Hypostoichiometric Low Pu Content (U,Pu)O<sub>2-x</sub> Mixed Oxide." *Journal of Nuclear Materials* 277:143-158.

13. Lanning, D.D., C.E. Beyer, and M.E. Cunningham. 2000. "FRAPCON-3 Fuel Rod Temperature Predictions with Fuel Conductivity Degradation Caused by Fission Products and Gadolinia Additions," in *Proceedings of the ANS International Topical Meeting on Light Water Reactor Fuel Performance, Park City, Utah, April 2000*, pages 261 to 274.
14. Lanning, D. D. and C. E. Beyer. 2001. "Assessment of Recent Data and Correlations for Fuel Pellet Thermal Conductivity," *Presented at Enlarged Halden Program Meeting March 11-16, 2001*, HPR-356.
15. American Nuclear Society (ANS). 1982. *Method for Calculating the Fractional Release of Volatile Fission Products from Oxide Fuel*, ANSI/ANS-5.4-9182. ANS 5.4 of the Standards Committee of the American Nuclear Society.
16. Forsberg, K. and A. R. Massih. 1985. "Diffusion Theory of Fission Gas Migration in Irradiated Nuclear Fuel  $\text{UO}_2$ ," *J. of Nucl. Mater.*, Vol. 135, pp. 140-148.
17. Regulatory Guide 1.126, Revision 1, "An Acceptable Model and Related Statistical Methods for the Analysis of Fuel Densification," 1978.
18. Letter, James Mallay (Framatome ANP) to NRC Document Control Desk, "Final Responses to RAIs on Chapter 13 of BAW-10231P," NRC:03:027, April 18, 2003.

Principle Contributor: S. Wu

Date: