

NOV 17 2003

LR-N03-0470



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 2
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **October 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Fricker", written over a horizontal line.

Carl J. Fricker
Salem Plant Manager

Attachments

C Distribution

IE24

DOCKET NO.: 50-311
 UNIT: Salem 2
 DATE: 11/11/03
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period October 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)
 No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

| | | |
|--------|--------------|------------|
| 1131 | | |
| 1092 | | |
| Month | Year-to-date | Cumulative |
| 212 | 6553 | 126969 |
| 212 | 6520 | 123478 |
| 0 | 0 | 0 |
| 233103 | 7205179 | 126394154 |

UNIT SHUTDOWNS

| NO. | DATE | TYPE F=FORCED S=SCHEDULED | DURATION (HOURS) | REASON (1) | METHOD OF SHUTTING DOWN THE REACTOR (2) | CORRECTIVE ACTION/ COMMENT |
|-----|--------------------------|---------------------------------|---------------------|---------------|--|-------------------------------|
| 3 | 10/9/03 - 10/31/03 | S | 533 Hrs. | C | 1 | Refuel Outage |

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-311
UNIT: Salem 2
DATE: 11/11/03
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 2 entered the month at approximately 100% power and remained there until October 9, when the unit was shutdown for a refueling outage.
- Salem 2 remained in the refueling outage at the end of the month.