



FPL

NOV 17 2003

L-2003-284
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - October 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the October 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Terry O. Jones
Vice President
Turkey Point Plant

LDT

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-251
UNIT: Turkey Point Unit 4
DATE: 11/04/03
COMPLETED BY: Linda Tudor
TELEPHONE: (305) 246-6408

Reporting Period October, 2003

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	120.0	6671	198033.7
No. of hours generator was on line (service hours)	120.0	6671	193616.2
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	39977	4597693	127556783

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20030022	10/06/2003	S	624.0	C	1	RF21

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power until September 21, 2003. A power coastdown then commenced and continued through October 5, 2003. On October 6, 2003, Unit 4 was manually tripped in accordance with plant procedures from approximately 30% power to commence the Cycle 21 refueling outage. Unit 4 went on-line on November 5, 2003.

DOCKET NO.: 50-250
UNIT: Turkey Point Unit 3
DATE: 11/04/2003
COMPLETED BY: Linda Tudor
TELEPHONE: (305) 246-6408

Reporting Period October, 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	745.0	6529.8	201069.2
No. of hours generator was on line (service hours)	745.0	6487.8	198696
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	529065	4442998	129802075

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power for the month of October 2003.