

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.9</p> <p style="text-align: center;">—————NOTE—————</p> <ol style="list-style-type: none"> 1. Credit may be taken for unplanned events that satisfy this SR. 2. If performed with DG synchronized with offsite power, it shall be performed at a power factor ≤ 0.9 <p>Verify each DG rejects a load greater than or equal to its associated single largest post accident load and following load rejection, the engine speed is maintained less than nominal plus 75% of the difference between nominal speed and the overspeed trip setpoint or 15% above nominal, whichever is lower.</p>	<p>18 months</p>
<p>SR 3.8.1.10</p> <p style="text-align: center;">—————NOTE—————</p> <p>Credit may be taken for unplanned events that satisfy this SR.</p> <p>Verify each DG operating at a power factor ≤ 0.9 does not trip and voltage is maintained ≤ 4784 V for DG 1A and DG 1B and ≤ 5400 V for DG 1C during and following a load rejection of a load ≥ 3030 kW and ≤ 3130 kW for DGs 1A and 1B and ≥ 2500 kW and ≤ 2600 kW for DG 1C.</p>	<p>18 months</p>

(continued)