

NOV 21 2003



PSEG
Nuclear LLC

LR-N03-0476
LCR H03-05

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**WITHDRAWAL OF REQUEST FOR ONE TIME ONLY CHANGE TO
TECHNICAL SPECIFICATIONS, CONTROL ROOM EMERGENCY
FILTRATION SYSTEM
HOPE CREEK GENERATING STATION
FACILITY OPERATING LICENSE NPF-57
DOCKET NO. 50-354**

Reference: Letter LRN-03-0217, *Request For Change To Technical
Specifications Control Room Emergency Filtration System*, dated
July 10, 2003

Letter LRN-03-0354, *Request For Change To Technical
Specifications Control Room Emergency Filtration System*, dated
August 14, 2003

By letters dated July 10, 2003, and August 14, 2003, PSEG Nuclear LLC (PSEG) proposed to change TS 3.7.2, CONTROL ROOM EMERGENCY FILTRATION SYSTEM, to allow the completion time required in ACTION a. to be extended up to 30 days, to implement repairs/upgrades to the control room emergency filtration (CREF) system chiller. PSEG requests that the requests in the referenced letters be withdrawn. However, PSEG may resubmit the request if warranted at a later date.


PSEG hereby withdraws its requests contained in both the July 10, 2003, and the August 14, 2003, letters for license amendment LCR H03-05.

A003

NOV 21 2003

If you have any questions or require additional information, please contact Mr. Michael Mosier at (856) 339-5434.

Sincerely,

A handwritten signature in black ink, appearing to read "Steven Mannon", written over the printed name.

Steven Mannon
Manager Nuclear Safety and Licensing

NOV 21 2003

C: Mr. H. Miller, Administrator – Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. J. Boska, Project Manager – Hope Creek
U. S. Nuclear Regulatory Commission
Mail Stop 08B1
Washington, DC 20555-0001

USNRC Senior Resident Inspector – Hope Creek (X24)

Mr. K. Tosch, Manager IV
Bureau of Nuclear Engineering
PO Box 415
Trenton, New Jersey 08625