

REACTOR COOLANT SYSTEM

OPERATING

LIMITING CONDITION FOR OPERATION

3.4.2.2 All pressurizer Code safety valves shall be OPERABLE with a lift setting¹ of 2485 psig + 2%, - 3%.²

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With one pressurizer Code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 1 hour or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.

SURVEILLANCE REQUIREMENTS

4.4.2.2 No additional requirements other than those required by Specification 4.0.5.

¹The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

²The as left lift setting shall be within $\pm 1\%$ following valve testing.