

### 3.5 EMERGENCY CORE COOLING SYSTEM (ECCS)

#### 3.5.2 ECCS - Operating

LCO 3.5.2 Two ECCS trains shall be OPERABLE.

APPLICABILITY: MODES 1 and 2,  
MODE 3 with pressurizer pressure  $\geq$  1750 psia.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more trains inoperable.</p> <p><u>AND</u></p> <p>At least 100% of the ECCS flow equivalent to a single OPERABLE ECCS train available.</p>	<p>A.1 Restore train(s) to OPERABLE status.</p>	72 hours
<p>B. Required Action and associated Completion Time not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Reduce pressurizer pressure to &lt; 1750 psia.</p>	<p>6 hours</p> <p>12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY												
SR 3.5.2.1	<p>Verify the following valves are in the listed position with power to the valve operator removed.</p> <table> <tr> <th><u>Valve Number</u></th><th><u>Position</u></th><th><u>Function</u></th></tr> <tr> <td>MOV-659</td><td>Open</td><td>Mini-flow Isolation</td></tr> <tr> <td>MOV-660</td><td>Open</td><td>Mini-flow Isolation</td></tr> <tr> <td>CV-306</td><td>Open</td><td>Low Pressure Safety Injection Flow Control</td></tr> </table>	<u>Valve Number</u>	<u>Position</u>	<u>Function</u>	MOV-659	Open	Mini-flow Isolation	MOV-660	Open	Mini-flow Isolation	CV-306	Open	Low Pressure Safety Injection Flow Control	12 hours
<u>Valve Number</u>	<u>Position</u>	<u>Function</u>												
MOV-659	Open	Mini-flow Isolation												
MOV-660	Open	Mini-flow Isolation												
CV-306	Open	Low Pressure Safety Injection Flow Control												
SR 3.5.2.2	Verify each ECCS manual, power-operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days												
SR 3.5.2.3	Verify each high pressure safety injection - and low pressure safety injection pump's developed head at the test flow point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program												
SR 3.5.2.4	Deleted													
SR 3.5.2.5	Verify each ECCS automatic valve that is not locked, sealed, or otherwise secured in position, in the flow path actuates to the correct position on an actual or simulated actuation signal.	24 months												