

December 15, 2003

Mr. Stephen A. Byrne
Senior Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1 - CORRECTION TO
AMENDMENT NO. 165 REGARDING REQUEST FOR A ONE-TIME
EXTENSION OF THE STEAM GENERATOR INSPECTION FREQUENCY
(TAC NO. MB7312)

Dear Mr. Byrne:

On October 29, 2003, the Nuclear Regulatory Commission issued Amendment No. 165 to Facility Operating License No. NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1. The amendment changed the Technical Specifications (TSs) in response to your application dated January 14, 2003, as supplemented by letters dated July 1, and August 20, 2003.

This amendment revised TS 4.4.5.3.a, maximum inspection interval from 40 calendar months to 58 calendar months after two consecutive inspections which were classified as C-1.

The amendment provided an attachment page that listed the pages to be removed from, and the new pages to be inserted in, the TSs. Page Nos. 3/4 4-19, B 3/4 4-3, B 3/4 4-5 were inadvertently left off this sheet and the pages were not included in the October 29, 2003, amendment. Enclosed are the corrected remove/insert page and the TS pages to be inserted in the amendment. We regret any inconvenience this may have caused.

Sincerely,

/RA/

Karen R. Cotton, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-395

Enclosures: 1. Remove/Insert Page
2. TS Pages

cc w/enclosures: See next page

December 15, 2003

Mr. Stephen A. Byrne
Senior Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1 - CORRECTION TO
AMENDMENT NO. 165 REGARDING REQUEST FOR A ONE-TIME
EXTENSION OF THE STEAM GENERATOR INSPECTION FREQUENCY
(TAC NO. MB7312)

Dear Mr. Byrne:

On October 29, 2003, the Nuclear Regulatory Commission issued Amendment No. 165 to Facility Operating License No. NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1. The amendment changed the Technical Specifications (TSs) in response to your application dated January 14, 2003, as supplemented by letters dated July 1, and August 20, 2003.

This amendment revised TS 4.4.5.3.a, maximum inspection interval from 40 calendar months to 58 calendar months after two consecutive inspections which were classified as C-1.

The amendment provided an attachment page that listed the pages to be removed from, and the new pages to be inserted in, the TSs. Page Nos. 3/4 4-19, B 3/4 4-3, B 3/4 4-5 were inadvertently left off this sheet and the pages were not included in the October 29, 2003, amendment. Enclosed are the corrected remove/insert page and the TS pages to be inserted in the amendment. We regret any inconvenience this may have caused.

Sincerely,

/RA/

Karen R. Cotton, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-395

Enclosures: 1. Remove/Insert Page
2. TS Pages

cc w/enclosures: See next page

DISTRIBUTION

PUBLIC

PDII-1 R/F

RidsNrrDlpmLpdii (EHackett)

RidsNrrDlpmLpdii-1 (JNakoski)

Package No.: ML033490314

ADAMS Accession No.: ML033490389

RidsNrrPMKCotton

RidsNrrLABClayton

RidsRgn2MailCenter (KLandis)

RidsAcrsAcnwMailCenter

TS: ML033450369

RidsOgcRp

TBoyce

G. Hill (2)

NRR-058

OFFICE	PM:PDII/S1	LA:PDII/S2	SC:PDII/S1
NAME	KCotton:sab	BClayton	JNakoski
DATE	12/11/03	12/10/03	12/15/03

OFFICIAL RECORD COPY

ATTACHMENT TO LICENSE AMENDMENT NO. 165

TO FACILITY OPERATING LICENSE NO. NPF-12

DOCKET NO. 50-395

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by an amendment number and contain marginal lines indicating the areas of change.

Remove Pages

3/4 4-13
3/4 4-19
B 3/4 4-3
B 3/4 4-5

Insert Pages

3/4 4-13
3/4 4-19
B 3/4 4-3
B 3/4 4-5

Mr. Stephen A. Byrne
South Carolina Electric & Gas Company

VIRGIL C. SUMMER NUCLEAR STATION

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, South Carolina 29065

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
576 Stairway Road
Jenkinsville, South Carolina 29065

Chairman, Fairfield County Council
Drawer 60
Winnsboro, South Carolina 29180

Mr. Henry Porter, Assistant Director
Division of Waste Management
Bureau of Land & Waste Management
Dept. of Health & Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. Jeffrey B. Archie, General Manager
Nuclear Plant Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 300
Jenkinsville, South Carolina 29065

Mr. Ronald B. Clary, Manager
Nuclear Licensing
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 830
Jenkinsville, South Carolina 29065

Ms. Kathryn M. Sutton, Esquire
Winston & Strawn Law Firm
1400 L Street, NW
Washington, DC 20005-3502