



Serial: RNP-RA/03-0155

DEC 09 2003

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

MONTHLY OPERATING REPORT

Ladies and Gentlemen:

In accordance with the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Technical Specifications Section 5.6.4, "Monthly Operating Reports," and HBRSEP, Unit No. 2, Technical Requirements Manual Section 6.2, "Monthly Operating Report," Progress Energy Carolinas, Inc., submits the attached report of operating statistics and shutdown experience for the month of November 2003.

If you have any questions concerning this matter, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. T. Baucom'.

C. T. Baucom
Supervisor – Licensing/Regulatory Programs

CTB/jwv

Attachment

c: NRC Resident Inspector, HBRSEP
L. A. Reyes, NRC, Region II
C. P. Patel, NRC, NRR

MONTHLY OPERATING REPORT

DOCKET NO. 050-0261

UNIT H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP), UNIT NO. 2

DATE 12/4/2003

COMPLETED BY TIM SURMA

TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2003

1. DESIGN ELECTRICAL RATING (NET MWE): 765
2. MAX DEPENDABLE CAPACITY (NET MWE): 710

	<u>THIS</u> <u>MONTH</u>	<u>YR TO</u> <u>DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR CRITICAL	720.00	8016.0	219813.99
4. HOURS GENERATOR ON LINE	720.00	8016.0	216494.26
5. UNIT RESERVE SHUTDOWN HOURS	0.00	0.00	23.20
6. NET ELEC. ENERGY GENERATED (MWH)	529668.00	5881647.00	141819105.00

Attachment to Serial: RNP-RA/03-0155

Page 2 of 2

DOCKET NO. 050-0261

UNIT NAME HBRSEP, UNIT NO. 2

DATE 12/4/2003

COMPLETED BY TIM SURMA

TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2003

UNIT SHUTDOWNS

No.	Date	Type	Duration (Hours)	Reason ¹	Method of Shutting Down the Reactor ²	Cause / Corrective Actions / Comments
		F: Forced S: Scheduled				

1

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

2

Method:

1-Manual

2-Manual Scram

3-Automatic Scram

4-Continuation

5-Other (Explain)

SUMMARY: The unit operated at approximately full power for the entire month. Power was reduced for approximately 17 hours to perform valve testing. There were no challenges to the pressurizer safety valves.