

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.2.1	<p>-----NOTES-----</p> <ul style="list-style-type: none"> - 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for SCIVs that are open under administrative controls. <p>-----</p> <ul style="list-style-type: none"> - <p>Verify each secondary containment isolation manual valve and blind flange that is not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p>	31 days
SR 3.6.4.2.2	Verify the isolation time of each power operated automatic SCIV is within limits.	In accordance with the Inservice Testing Program
SR 3.6.4.2.3	Verify each automatic SCIV actuates to the isolation position on an actual or simulated actuation signal.	18 months