

# **ENERGY NORTHWEST**

P.O. Box 968 ■ Richland, Washington 99352-0968

December 8, 2003  
GO2-03-182

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397  
MONTHLY OPERATING REPORT  
NOVEMBER 2003**

Dear Sir or Madam:

Transmitted herewith is the Monthly Operating Report for the month of November 2003 as required by Technical Specification 5.6.4.

Respectfully,



WS Oxenford  
Plant General Manager  
Mail Drop 927M

Attachment

cc: BS Mallett - NRC RIV  
BJ Benney - NRC NRR  
NRC Senior Resident Inspector - 988C  
TC Poindexter - Winston & Strawn  
INPO  
ANI Library  
Utility Data Institute  
RN Sherman - BPA / 1399

JE24

**OPERATING STATUS REPORT**  
for Columbia Generating Station

Date: December 1, 2003

---

1. Docket: 50-397
2. Reporting Period: November 2003
3. Utility Contact: **Patricia Campbell** (509) 377-4664
4. Design Electrical Rating (Net MWe): 1153
5. Maximum Dependable Capacity - summer (Net MWe): 1107

|                                | MONTH   | YEAR      | CUMULATIVE  |
|--------------------------------|---------|-----------|-------------|
| 6. Hours Reactor Critical      | 720.0   | 6,419.0   | 126,114.5   |
| 7. Hours Generator On-Line     | 720.0   | 6,298.1   | 122,669.6   |
| 8. Unit Reserve Shutdown Hours | 0.0     | 0.0       | 3,274.7     |
| 9. Net Electrical Energy (MWH) | 806,785 | 6,783,709 | 122,036,488 |

## UNIT SHUTDOWNS

DOCKET NO.: 50-397  
 UNIT NAME: Columbia Generating Station  
 DATE: December 1, 2003  
 COMPLETED BY: P. Campbell  
 TELEPHONE: (509) 377-4664

REPORT PERIOD: November, 2003

| No. | Date | Type<br>F: Forced<br>S: Scheduled | Duration<br>(Hours) | Reason (1) | Method of<br>Shutting<br>Down (2) | Cause / Corrective Actions<br>Comments |
|-----|------|-----------------------------------|---------------------|------------|-----------------------------------|--|
| NA  |      |                                   |                     |            |                                   |  |

**SUMMARY:** The plant began and ended the month at 100% power.

### (1) REASON

|                            |  |
|----------------------------|--|
| A - Equipment Failure      | E - Operator Training &<br>License Examination |
| B - Maintenance or Test    | F - Administration                             |
| C - Refueling              | G - Operational Error                          |
| D - Regulatory Restriction | H - Other                                      |

### (2) METHOD

1 - Manual  
 2 - Manual Trip/Scram  
 3 - Auto Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)