

**From:** Claude Johnson  
**To:** CSM  
**Date:** 6/18/03 10:48AM  
**Subject:** Fwd: FYI: possible TIA on manual actions

fyi

Information in this record was deleted  
in accordance with the Government Information  
Act, Exemptions 5  
FOIA- 2003-358

R/19

From: Rebecca Nease  
 To: Weerakkody, Sunil  
 Date: 6/13/03 9:34AM  
 Subject: FYI: possible TIA on manual actions

Congratulations on being selected fire protection section chief, and welcome to the NRC's fire protection world.

I have recently been selected as the Engr/Maint Branch Team Leader in Region IV, and as such will be handling the region's implementation of the fire protection inspection program.

I want to give you a "heads-up" on two similar licensing basis issues we have identified at post -1979 sites. The issues involve changes the licensees made to their fire protection program (FPP) in which manual actions were implemented in lieu of providing the physical protection required in 10 CFR Part 50 Appendix R, Section III.G.2.

[REDACTED]  
 Post-1979 plant - committed to III.G.2 - has the standard FP license conditions. The licensee removed Thermo-Lag and implemented manual actions to mitigate the effects of fire damage. They have procedures describing these manual actions.

[REDACTED]

5

5

5

[REDACTED]

5

CC: Johnson, Claude; Marschall, Charles; Mullikin, Ray