

January 9, 2004

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Mr. Russell Arrighi (Mail Stop O-11F1)
Office of Nuclear Reactor Regulation
Washington, D.C. 20555-0001

Subject: CI 2.3.3.5-1
R. E. Ginna Nuclear Power Plant
Docket No. 50-244


Dear Mr. Arrighi:

The purpose of this letter is to supplement our response to CI 2.3.3.5-1, dated December 9, 2003. As stated in that response, Ginna Station's design basis does not rely on forced control room cooling to maintain control room habitability in the event of an accident. An evaluation was performed to calculate limiting post-LOCA control room conditions, and it was shown that temperatures required for reliable equipment operation were maintained without forced cooling.

Please address any issues regarding this letter to our License Renewal Project Manager, George Wrobel, at (585) 771-3535.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by RG&E to make this submittal and that the foregoing is true and correct.

Very truly yours,



Robert C. Mecredy

Executed on January 9, 2004

An equal opportunity employer

89 East Avenue | Rochester, NY 14649
tel (585) 546-2700

www.rge.com

1000920

A092

cc: Mr. Russ Arrighi, Project Manager (Mail Stop O-11F1)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. Robert G. Schaaf (Mail Stop O-11F1)
Office of Nuclear Regulatory Regulation
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. Robert L. Clark (Mail Stop O-8-C2)
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Regulatory Regulation
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

U.S. NRC Ginna Senior Resident Inspector

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406