

March 9, 2004

MEMORANDUM TO: Stephen Dembek, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Jack Donohew, Senior Project Manager, Section 2 **/RA/**
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: FORTHCOMING MEETING WITH UNION ELECTRIC COMPANY ON
CALLAWAY PLANT, UNIT 1 (TAC NO. MC1756)

DATE & TIME: Tuesday, March 23, 2004
9:30 a.m. - 4:30 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike, Room 7-B-2
Rockville, Maryland

PURPOSE: The licensee requested the meeting to explain its application dated
December 17, 2003, to revise Technical Specifications (TSs) 3.3.1,
"Reactor Trip System (RTS) Instrumentation," 3.3.2, "Engineered Safety
Feature Actuation System (ESFAS) Instrumentation," and 3.3.9, "Boron
Dilution Mitigation System (BDMS)." A notice of this application was
published in the *Federal Register* on February 3, 2004 (69 FR5211).

CATEGORY:* This is a Category 1 Meeting. The public is invited to observe this
meeting and will have one or more opportunities to communicate with the
NRC after the business portion, but before the meeting is adjourned.

PARTICIPANTS: NRC Participants are in the Office of Nuclear Reactor Regulation (NRR)

<u>NRC</u>	<u>UTILITY</u>
J. Donohew, et al.	S. Wideman (Wolf Creek)
	B. Yates

Docket No. 50-483

Attachment: Agenda (Adams Accession No. ML040690115)

cc w/att: See next page

MEETING CONTACTS: Jack Donohew, NRR Alan Wang, NRR
301-415-1307 301-415-1445
jnd@nrc.gov abw@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings," 67 FR 36920, May 28, 2002.

March 9, 2004

MEMORANDUM TO: Stephen Dembek, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Jack Donohew, Senior Project Manager, Section 2 **/RA/**
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: FORTHCOMING MEETING WITH UNION ELECTRIC COMPANY ON
CALLAWAY PLANT, UNIT 1 (TAC NO. MC1756)

DATE & TIME: Tuesday, March 23, 2004
9:30 a.m. - 4:30 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike, Room 7-B-2
Rockville, Maryland

PURPOSE: The licensee requested the meeting to explain its application dated December 17, 2003, to revise Technical Specifications (TSs) 3.3.1, "Reactor Trip System (RTS) Instrumentation," 3.3.2, "Engineered Safety Feature Actuation System (ESFAS) Instrumentation," and 3.3.9, "Boron Dilution Mitigation System (BDMS)." A notice of this application was published in the *Federal Register* on February 3, 2004 (69 FR5211).

CATEGORY:* This is a Category 1 Meeting. The public is invited to observe this meeting and will have one or more opportunities to communicate with the NRC after the business portion, but before the meeting is adjourned.

PARTICIPANTS: NRC Participants are in the Office of Nuclear Reactor Regulation (NRR)

NRC
J. Donohew, et al.

UTILITY
S. Wideman (Wolf Creek)
B. Yates

Docket No. 50-483

Attachment: Agenda (Adams Accession No. ML040690115)

cc w/att: See next page

MEETING CONTACTS: Jack Donohew, NRR Alan Wang, NRR
301-415-1307 301-415-1445
jnd@nrc.gov abw@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings," 67 FR 36920, May 28, 2002.

ACCESSION NO.: ML040690115 NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JDonohew	EPeyton	RGramm for SDembek
DATE	3/9/04	3/9/04	3/9/04

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML040690115.wpd
OFFICIAL RECORD COPY

FORTHCOMING MEETING WITH UNION ELECTRIC COMPANY ON MARCH 23, 2004

Dated: March 9, 2004

DISTRIBUTION:

Hard Copy

PUBLIC

PDIV-2 R/F

Receptionists OWFN/TWFN

JDonohew

E-mail

RidsNrrAdpt(BSheron/MKing)

RidsNrrDlpm(TMarsh/ELeeds)

RidsNrrDlpmLpdiv(HBerkow)

RidsNrrSCSDembek

RidsNrrPMJ Donohew

RidsNrrLAEPeyton

RidsOPAMailCenter

RidsOGCMailCenter

RidsACRS/ACNWMailCenter

RidsRgnIVMailCenter (KEBrockman,DGraves/RKopriva,BHenderson)

DJackson, EDO

JAlbright

PMNS

Callaway Plant, Unit 1

cc:

Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855

John O'Neill, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. Mark A. Reidmeyer, Regional
Regulatory Affairs Supervisor
Regulatory Affairs
AmerenUE
P.O. Box 620
Fulton, MO 65251

U.S. Nuclear Regulatory Commission
Resident Inspector Office
8201 NRC Road
Steedman, MO 65077-1302

Mr. Chris Younie
Manager, Quality Assurance
AmerenUE
P.O. Box 620
Fulton, MO 65251

Manager - Electric Department
Missouri Public Service Commission
301 W. High
P.O. Box 360
Jefferson City, MO 65102

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Mr. Ronald A. Kucera
Deputy Director for Public Policy
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Mr. Rick A. Muench
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, KA 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition for the
Environment
6267 Delmar Boulevard
University City, MO 63130

Mr. Lee Fritz, Presiding Commissioner
Callaway County Court House
10 East Fifth Street
Fulton, MO 65151

Mr. David E. Shafer
Superintendent, Licensing
Regulatory Affairs
AmerenUE
P.O. Box 66149, MC 470
St. Louis, MO 63166-6149

Mr. Keith D. Young
Manager, Regulatory Affairs
AmerenUE
P.O. Box 620
Fulton, MO 65251

Mr. Scott Clardy, Director
Section for Environmental Public Health
P.O. Box 570
Jefferson City, MO 65102-0570

Certrec Corporation
4200 South Hulen, Suite 630
Fort Worth, TX 76109

Mr. Garry L. Randolph
Vice President and
Chief Nuclear Officer
Union Electric Company
Post Office Box 620
Fulton, MO 65251

AGENDA

MEETING WITH UNION ELECTRIC COMPANY – CALLAWAY PLANT, UNIT 1

MARCH 23, 2004

- Introduction
- Discussion of Amendment Request dated December 17, 2003
 - The amendment would revise Technical Specifications (TSs) 3.3.1, 3.3.2, and 3.3.9. The purpose is to adopt the completion time, test bypass time, and surveillance frequency time changes approved by the NRC in Topical Reports WCAP-14333-P-A, "Probabilistic Risk Analysis of the RPS [reactor protection system] and ESFAS [engineered safety features actuation system] Test Times and Completion Times," and WCAP-15376-P-A, "Risk-Informed Assessment of the RTS and ESFAS Surveillance Test Intervals and Reactor Trip Breaker Test and Completion Times."
 - The proposed changes would revise the required actions for certain action conditions; increase the completion times for several required actions (including some notes); delete notes in certain required actions; increase frequency time intervals (including certain notes) in several surveillance requirements (SRs); add an action condition and required actions; revise notes in certain SRs; and revise Table 3.3.2-1.
 - The licensee will discuss the proposed changes, background, technical analysis, and regulatory analysis given in the application.

PUBLIC COMMENTS

- Adjourn Meeting