

10 CFR 72.212(b)(1)(ii)

May 17, 2004

2130-04-20115

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington DC 20555

Subject: Oyster Creek Generating Station  
Docket 72-15  
Registration of Independent Spent Fuel Storage Installation  
Casks No. 9,10, and 11

In accordance with 10 CFR 72.212(b)(1)(ii), this letter docket the use of the following casks in the Oyster Creek Generating Station Independent Spent Fuel Storage Installation:

<u>Cask Certificate No.</u>	<u>Cask Model No.</u>	<u>Cask ID No.</u>	<u>Date Loaded</u>
72-1004 (Amendment 7)	NUHOMS-61BT	OCG61B-009-C	04/17/2004
72-1004 (Amendment 7)	NUHOMS-61BT	OCG61B-010-C	04/24/2004
72-1004 (Amendment 7)	NUHOMS-61BT	OCG61B-011-C	05/06/2004

Additionally, the following thermal performance data was collected.

<u>Cask / Horizontal Storage Module No.</u>	<u>OCG61B-009-C/HSM-915-009</u>
Decay Heat Load	7.3 KW
Forecast Temperature Rise	39 Degrees F
Actual Temperature Rise	31.4 Degrees F

<u>Cask / Horizontal Storage Module No.</u>	<u>OCG61B-010-C/HSM-915-010</u>
Decay Heat Load	7.3 KW
Forecast Temperature Rise	39 Degrees F
Actual Temperature Rise	26.0 Degrees F

<u>Cask / Horizontal Storage Module No.</u>	<u>OCG61B-011-C/HSM-915-011</u>
Decay Heat Load	7.3 KW
Forecast Temperature Rise	39 Degrees F
Actual Temperature Rise	31.5 Degrees F


UMSS01

2130-04-20115

Page 2

If any further information or assistance is required, please contact Mr. David Fawcett of my staff at 609.971.4284.

Very truly yours,

A handwritten signature in black ink, appearing to read "C. N. Swenson", written over the typed name.

C. N. Swenson, Vice President  
Oyster Creek Generating Station

cc: Administrator, Region I  
NRC Senior Project Manager  
NRC Senior Resident Inspector  
Spent Fuel Project Manager, Randy Hall  
File No: 02018