September 2, 2004

U.S. NUCLEAR REGULATORY COMMISSION REGION I

NOTICE OF SIGNIFICANT LICENSEE MEETING

No. 04-26

Licensee: Exelon Generation Company, LLC

Facility: Oyster Creek Generating Station

Docket Nos.: 50-219

Time and Date: 1:00 P.M. on Monday, September 27, 2004

Location: Region I Office

Public Meeting Room 475 Allendale Road

King of Prussia, PA 19406

Purpose: Regulatory Conference at Exelon's request to discuss Exelon's evaluation and

any differences with the NRC evaluation of a preliminarily Greater Than Green finding. This finding involved a failure to follow procedures while replacing the cooling fan drive belts of the No.1 emergency diesel generator cooling system during an overhaul in April 2004. The finding does not present an immediate safety concern. This preliminarily Greater Than Green finding is documented in NRC Inspection Report 05000219/2004003, (ADAMS Ascension Number

ML042260078). ADAMS is accessible from the NRC Web site at

http://www.nrc.gov/reading-rm/adams.html (The Public Electronic Reading

Room).

NRC Attendees: S. Collins, Regional Administrator

A. Blough, Director, Division of Reactor Projects W. Lanning, Director, Division of Reactor Safety

P. Eselgroth, Chief, Projects Branch 7

D. Holody, Tech Leader, Tech Program Staff J. Herrera, Resident Inspector, Oyster Creek

R. Barkley, P.E., Senior Project Engineer, Projects Branch 7

K. Farrar, Regional Counsel

Licensee Attendees: W. Levis, Vice President, Mid-Atlantic Regional Operating Group

J. Benjamin, Vice President, Licensing & Regulatory Affairs

A. Shahkarami, Vice President, Engineering

B. Swenson, Site Vice President, Oyster Creek Generating StationM. Massaro, Plant Manager, Oyster Creek Generating StationJ. Magee, Engineering Director, Oyster Creek Generating Station

M. Gallagher, Director, Mid-Atlantic Licensing

S. Hutchins, Engineering Manager, Oyster Creek Generating Station

D. Vanover, ERIN Engineering, PRA Specialist

Note: This meeting is open to the public for observation. This is a Category 1 Meeting: The public is invited to observe the meeting and will have one or more opportunities to communicate with the NRC after the business portion, but before the meeting is adjourned. Attendance by additional NRC personnel or handicapped persons requiring assistance to attend or participate in the meeting should be made known by September 25, 2004, to Mr. Peter W. Eselgroth, Region I, at 610-337-5234.

/RA by Richard S. Barkley

Approved By: <u>Acting for/</u>

Mr. Peter W. Eselgroth, Chief

Projects Branch 7

Division of Reactor Projects

Meeting Contact: Mr. Peter W. Eselgroth, Chief, Projects Branch 7

610-337-5234

(email address - pwe@nrc.gov)

Distribution:

Mr. John L. Skolds, Chief Operating Officer Regional Administrator Secretary, RI Deputy Regional Administrator Secretary, RI DRP Division Secretary, RI DRS Division Secretary, RI DRM Division Secretary, RI DNMS Division Secretary, RI Region I Receptionist State of New Jersey

<u>Distribution (Via E-Mail)</u>:

- L. Reyes, Executive Director for Operations, OEDO
- E. Merschoff, Deputy Executive Director for Reactor Programs, OEDO
- J. Dyer, Director, Office of Nuclear Reactor Regulation (NRR)
- J. Craig, Deputy Director, Office of Nuclear Regulatory Research (NRR/OD)
- D. Mathews, Director, Division of Regulatory Improvement Programs, NRR
- B. Boger, Director, Division of Inspection Program Management, NRR
- F. Congel, Director, Office of Enforcement
- L. Marsh, Director, Division of Licensing Project Management, NRR
- C. Holden, Project Directorate I-1 (PD1/2), NRR
- C. Miller, EDO Coordinator, OEDO
- D. Screnci, Senior Public Affairs Officer, RI
- N. Sheehan, Field Public Affairs Officer, RI
- G. Matakas, ORA
- R. Bores, ORA
- W. Lanning, DRS
- R. Crlenjak, DRS
- R. Summers, SRI-Oyster Creek, DRP
- S. Bogle, OE
- T. Reis, NRR
- R. Urban, ORA

PMNS

NRCWEB

OEWEB

OEMAIL

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML042510029.WPD

After declaring this document "An Official Agency Record" it <u>will/will not</u> be released to the Public. To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP		RI/ORA		RI/DRP	
NAME	JHernandez/ JEH		RUrban/ RJU		Peselgroth/RSB for	
DATE	09/01/04		09/02/04		09/02/04	

OFFICIAL RECORD COPY