

November 12, 2004

LICENSEE: Indiana Michigan Power Company

FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
OCTOBER 19, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND INDIANA MICHIGAN POWER COMPANY, PERTAINING
TO THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2, LICENSE
RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the NRC or the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information (RAIs) concerning the Donald C. Cook Nuclear Plant, Units 1 and 2, license renewal application (LRA). The conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains the item discussed with the applicant, including a brief description on the status of the item.

The applicant has had an opportunity to comment on this summary.

/RA/

Jonathan G. Rowley, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/encls: See next page

November 12, 2004

LICENSEE: Indiana Michigan Power Company

FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
OCTOBER 19, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND INDIANA MICHIGAN POWER COMPANY, PERTAINING
TO THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2, LICENSE
RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the NRC or the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information (RAIs) concerning the Donald C. Cook Nuclear Plant, Units 1 and 2, license renewal application (LRA). The conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains the item discussed with the applicant, including a brief description on the status of the item.

The applicant has had an opportunity to comment on this summary.

/RA/

Jonathan G. Rowley, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/encls: See next page

ADAMS Accession No.: **ML043170666**

DOCUMENT NAME: E:\Filenet\ML043170666.wpd

OFFICE	PM:RLEP	LA:RLEP	SC:RLEP
NAME	JRowley	YEdmonds	SLee
DATE	11/9/04	11/9/04	11/12/04

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
2443 Warrenville Road, Suite 210
Lisle, IL 60532-4351

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Mr. John A. Zwolinski
Director, Design Engineering and
Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Patricia Loughheed
2443 Warrenville Rd.
Lisle, IL 60532

Michigan Department of Environmental
Quality
Waste and Hazardous Materials Div.
Hazardous Waste & Radiological
Protection Section
Nuclear Facilities Unit
Constitution Hall, Lower-Level North
525 West Allegan Street
P.O. Box 30241
Lansing, MI 48909-7741

Michael J. Finissi, Plant Manager
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mr. Joseph N. Jensen, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mr. Fred Emerson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708

Richard J. Grumbir
Project Manager, License Renewal
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Mr. Mano K. Nazar
Senior Vice President and Chief Nuclear
Officer
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

DISTRIBUTION: Licensee: Indiana Michigan Power Co., Re: Donald C.Cook Plant, Units 1 and 2, Dated: November 12, 2004 Accession No: **ML043170666**

HARD COPY

RLEP RF

J. Rowley (PM)

E-MAIL:

RidsNrrDrip

RidsNrrDe

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

R. Jenkins

P. Shemanski

J. Fair

RidsNrrDssa

RidsNrrDipm

D. Thatcher

R. Pettis

C. Li

M. Itzkowitz (RidsOgcMailCenter)

R. Weisman

M. Mayfield

A. Murphy

S. Smith (srs3)

S. Duraiswamy

Y. L. (Renee) Li

RLEP Staff

K. Coyne

L. Lund

S. Coffin

T. Chan

R. Gramm

A. Howell

M. Shuaibi

J. Strasma, RIV

M. Kotzalas

OPA

NRR/ADPT secretary (RidsNrrAdpt)

LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL
TO DISCUSS THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION
OCTOBER 19, 2004

Participants

Jonathan Rowley
Om Chopra
Robert Kalinowski
Neil Haggerty
Roger Rucker
Mike Stroud

Affiliations

U.S. Nuclear Regulatory Commission (NRC)
NRC
Indiana Michigan Power Company (I&M)
I&M
Entergy*
Entergy

* I&M Contractor

**REQUEST FOR ADDITIONAL INFORMATION
DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

OCTOBER 19, 2004

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information concerning the Donald C. Cook Nuclear Plant, Units 1 and 2 (CNP), license renewal application (LRA).

RAI 3.6-2 and RAI 3.6-5

The staff pointed out a discrepancy between the supplemental responses to the request for additional information (RAI) 3.6-2 (letter AEP:NRC:4034-17) and RAI 3.6-5 (letter AEP:NRC:4034-15).

Additional Information Requested

The staff requested that the applicant clarify which version of the Non-EQ Instrumentation Circuits Test Review Program stated in the two letters is correct.

Status

The part of each response detailing the Non-EQ Instrumentation Circuits Test Review Program should have been the same but were not. The applicant acknowledged the error and provided a correction which is a combination of the two responses. The original two versions of the Non-EQ Instrumentation Circuits Test Review Program and the combination are provided below. The applicant will submit this information on the docket.

From letter AEP:NRC:4034-15

A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals, such as radiation monitoring and nuclear instrumentation, which are exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope at a frequency not to exceed 10 years or as part of

Enclosure 2

corrective actions when acceptance criteria are exceeded at the normal calibration frequency. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.

From letter AEP:NRC:4034-17

A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope. A proven cable test for detecting insulation deterioration on in-scope instrumentation cables that are disconnected during calibration will be performed at a frequency determined by engineering evaluation, but will not be less than once per ten years. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.

Combined:

A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals, such as radiation monitoring and nuclear instrumentation, which are exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope at a frequency of not less than once per ten years or as part of corrective actions when acceptance criteria are exceeded at the normal calibration frequency. A proven cable test for detecting insulation deterioration on in-scope instrumentation cables that are disconnected during calibration will be performed at a frequency determined by engineering evaluation, but will not be less than once per ten years. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.