



FPL

NOV 10 2004

L-2004-260
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - October 2004

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the October 2004 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Terry O. Jones
Vice President
Turkey Point Plant

RLE

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 11/02/2004
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period October, 2004

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	0	6469.1	209002.3
No. of hours generator was on line (service hours)	0	6396.7	206537.2
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	0	4463145	135267790

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20040019	9/26/04	S	745	C	4	CYCLE 21 REFUELING OUTAGE

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G -Operational Error (Explain)
 H -Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 had been shut down September 26, 2004 and was down the entire month of October for the Cycle 21 refueling outage.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 11/02/2004
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period October, 2004

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	745	7278.9	206698.7
No. of hours generator was on line (service hours)	745	7225.5	202203.9
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	529043	5052793	133574361

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of October, 2004