

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.8.1-1 to determine which SRs apply for each LOP Function.
2. When a 4.16 kV Emergency Bus Undervoltage channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains initiation capability (for Functions 1 and 2) and annunciation capability (for Function 3).

SURVEILLANCE		FREQUENCY
SR 3.3.8.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.8.1.2	Perform CHANNEL FUNCTIONAL TEST.	31 days
SR 3.3.8.1.3	Perform CHANNEL CALIBRATION.	18 months
SR 3.3.8.1.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

BASES

**SURVEILLANCE
REQUIREMENTS**

SR 3.3.8.1.4 (continued)

The system functional testing performed in LCO 3.8.1 and LCO 3.8.2 overlaps this Surveillance to provide complete testing of the assumed safety functions.

The 24 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. The 24 month frequency is further based on a review of surveillance test history.

REFERENCES

1. FSAR, Section 8.4.
 2. FSAR, Section 4.8.
 3. FSAR, Section 6.5.
 4. FSAR, Chapter 14.
 5. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
-

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.8.1-1 to determine which SRs apply for each LOP Function.
2. When a 4.16 kV Emergency Bus Undervoltage channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains initiation capability (for Functions 1 and 2) and annunciation capability (for Function 3).

SURVEILLANCE		FREQUENCY
SR 3.3.8.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.8.1.2	Perform CHANNEL FUNCTIONAL TEST.	31 days
SR 3.3.8.1.3	Perform CHANNEL CALIBRATION.	18 months
SR 3.3.8.1.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

BASES

**SURVEILLANCE
REQUIREMENTS**

SR 3.3.8.1.4 (continued)

The system functional testing performed in LCO 3.8.1 and LCO 3.8.2 overlaps this Surveillance to provide complete testing of the assumed safety functions.

The 24 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. The 24 month frequency is further based on a review of surveillance test history.

REFERENCES

1. FSAR, Section 8.3.1.
 2. FSAR, Section 5.2.
 3. FSAR, Section 6.3.
 4. FSAR, Chapter 15.
 5. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
-