



LR-E04-0523

November 19, 2004


New Jersey Department of
Environmental Protection
Division of Water Quality
Bureau of Permit Management
P.O. Box 029
Trenton, NJ 08625-0029
Certified Mail Number 7003 0500 0003 4363 8923

**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORTS
SALEM GENERATING STATION
PERMIT NO. NJ0005622**

Attached is the Discharge Monitoring Report for Salem Generating Station containing the information as required in Permit No. NJ0005622, for the month of October 2004.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analyses required to be performed by the above agencies. The choice of the measurement devices and analytical methods is controlled by EPA and NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or any reading or analytical result represents, the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

Sincerely,


Michael H. Brothers
Vice President
Site Operations

Attachments

IE23

NJPDES Report
October 2004

C . Executive Director – DRBC
USNRC – Document Control Desk Unit#1-50-272 Unit#2-50-311
Director – Nuclear Safety & Licensing
C. McAuliffe, Esq.
D. Hurka
E. Keating
SCH04-040

NJPDES Report
Explanation of Deviations
October 2004

The following excursions are included in the attached report and are explained below. Excursions have not endangered nor significantly impacted public health or the environment.


<u>DSN NO.</u>	<u>EXPLANATION</u>
----------------	--------------------

None	
------	--


COUNTY OF SALEM
STATE OF NEW JERSEY

I, Michael H. Brothers, of full age, being duly sworn according to law, upon my oath depose and say:

1. I Michael H. Brothers, Vice President of Site Operations for PSEG Nuclear, and as such, am authorized to sign Salem's Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I have reviewed the attached Discharge Monitoring Reports. Pursuant to N.J. A. C. 7:14A-2.4, I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that based on my inquiry of those individuals responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.


Michael H. Brothers
Vice President
Site Operations

Sworn and subscribed before me
this 18 day of Nov 2004



Commission expires 11/15/09

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	FACA – SW Outfall FACA
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:
PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000


REPORT RECIPIENT:
PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	11/19/2004 856-339-2900
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:


FACILITY NAME:

NJ0005622

FACA SW Outfall FACA

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC	SAMPLE MEASUREMENT	*****	*****		*****	18.0	21.8		Q	Continuous	CONTIN
00010 G Raw Sew/Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		Continuous	CONTIN
	QL	*****	*****		*****	*****	*****				
Temperature, oC	SAMPLE MEASUREMENT	*****	*****		*****	26.8	30.8		Q	Continuous	CONTIN
00010 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	43.3 01DAMX	DEG.C		Continuous	CONTIN
	QL	*****	*****		*****	*****	*****				
Temperature, oC	SAMPLE MEASUREMENT	*****	*****		*****	8.8	10.2		Q	1/DAY	CALCTD
00010 2 Effluent Net Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	15.3 01DAMX	DEG.C		1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA343	17451					
99999 99 Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applc	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	FACB – SW Outfall FACB
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACB SW Outfall FACB

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	18.0	21.8			Continuous	CONTIN
00010 G Raw Sew/influent	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		Continuous	CONTIN
	QL	*****	*****		*****	*****	*****				
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	27.5	32.0			Continuous	CONTIN
00010 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	43.3 01DAMX	DEG.C		Continuous	CONTIN
	QL	*****	*****		*****	*****	*****				
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	9.5	10.4			1/DAY	CALCTD
00010 2 Effluent Net Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	15.3 01DAMX	DEG.C		1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
99999 99 Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	FACC – SW Outfall FACC
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:
PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:
PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACC SW Outfall FACC

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 G Raw Sew/Influent	SAMPLE MEASUREMENT	2311	2593	MGD	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	3024 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
Thermal Discharge Million BTUs per Hr 00015 2 Effluent Net Value	SAMPLE MEASUREMENT	13716	14558	MBTU/HR	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	30600 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	048C – SW Outfall 48C
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:
PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000


REPORT RECIPIENT:
PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	11/19/2004 856-339-2900
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:


FACILITY NAME:

NJ0005622

048C SW Outfall 48C

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant	SAMPLE MEASUREMENT	0.1423	0.3815	MGD	*****	*****	*****	*****	<input checked="" type="checkbox"/>	1/DAY	CALCTD
50050 1	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		<input checked="" type="checkbox"/>	1/Day	CALCTD
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	4	8	MG/L	<input checked="" type="checkbox"/>	2/month	COMPOS
00530 1	PERMIT REQUIREMENT	*****	*****		*****	30 01MOAV	100 01DAMX			2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Nitrogen, Ammonia Total (as N)	SAMPLE MEASUREMENT	*****	*****	*****	*****	14	15	MG/L	<input checked="" type="checkbox"/>	2/month	COMPOS
00610 1	PERMIT REQUIREMENT	*****	*****		*****	35 01MOAV	70 01DAMX			2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Petroleum Hydrocarbons	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.5	<0.5	MG/L	<input checked="" type="checkbox"/>	2/month	GRAB
00551 1	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX			2/Month	GRAB
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Carbon, Tot Organic (TOC)	SAMPLE MEASUREMENT	*****	*****	*****	*****	12	14	MG/L	<input checked="" type="checkbox"/>	2/month	COMPOS
00680 1	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX			2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4680 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	481A – SW Outfall 481A
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:
PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000


REPORT RECIPIENT:
PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	11/19/2004 856-339-2900
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

481A SW Outfall 481A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	471	484	MGD	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.6	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.8	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE = N	*****	*****	%EFFL	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****			2/Year	COMPOS
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE = N	CODE = N	MG/L	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	< 0.1	< 0.1	MG/L	Q	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

481A SW Outfall 481A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	26.6	33.9		1	1/DAY	CONTIN
00010 1	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	482A – SW Outfall 482A
		Month	Day	Year										
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

11/19/2004
DATE

856-339-2900
AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

005622

482A SW Outfall 482A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant	SAMPLE MEASUREMENT	341	454		*****	*****	*****		Q	1/DAY	CALCTD
50050 1 Effluent Gross Value	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX	MGD	*****	*****	*****	*****		1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****		7.4	*****	7.5		Q	1/WEEK	GRAB
00400 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	6.0 01DAMN	*****	9.0 01DAMX	SU		1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****		7.7	*****	7.8		Q	1/WEEK	GRAB
00400 7 Intake From Stream	PERMIT REQUIREMENT	*****	*****	*****	REPORT 01DAMN	*****	REPORT 01DAMX	SU		1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon	SAMPLE MEASUREMENT	*****	*****		CODE = N	*****	*****		Q	CODE = N	CODE = N
TANGA 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	.50 01DAMN	*****	*****	%EFFL		2/Year	COMPOS
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants	SAMPLE MEASUREMENT	*****	*****		*****	CODE = N	CODE = N		Q	CODE = N	CODE = N
*CPOX 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	0.3 01MOAV	0.5 01DAMX	MG/L		3/Week	GRAB
Option 1	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants	SAMPLE MEASUREMENT	*****	*****		*****	<0.1	<0.1		Q	3/WEEK	GRAB
*CPOX 1 Effluent Gross Value	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	0.2 01DAMX	MG/L		3/Week	GRAB
Option 2	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NO. 555622

482A SW Outfall 482A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	27.4	32.3		Q	1/DAY	CONTIN
00010 1	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	483A – SW Outfall 483A
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

11/19/2004

DATE

856-339-2900

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

483A SW Outfall 483A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	426	455	MGD	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.6	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.8	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE = N	CODE = N	MG/L	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	Q	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	26.8	31.8	DEG.C	Q	1/DAY	CONTIN
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER: NJ0005622
 MONITORED LOCATION: 483A SW Outfall 483A
 MONITORING PERIOD: 10/1/2004 TO 10/31/2004
 FACILITY NAME: PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA343	17451					
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	484A – SW Outfall 484A
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

N3005622

484A SW Outfall 484A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	434	445	MGD	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.5	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.8	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE = N	*****	*****	%EFFL	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****			2/Year	COMPOS
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE = N	CODE = N	MG/L	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	Q	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER: NJC005622
 MONITORED LOCATION: 484A SW Outfall 484A
 MONITORING PERIOD: 10/1/2004 TO 10/31/2004
 FACILITY NAME: PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, °C 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****	27.6	33.4		8	1/DAY	CONTIN
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic.	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	485A – SW Outfall 485A
	10	1	2004		10	31	2004	

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐ No Discharge this Monitoring Period

☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:


FACILITY NAME:

NJ0005622

485A SW Outfall 485A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC


PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	383	427	MGD	*****	*****	*****	*****	Q	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.7	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.8	SU	Q	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
LC50 Statro 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE = N	*****	*****	%EFFL	Q	CODE = N	CODE = N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE = N	CODE = N	MG/L	Q	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	< 0.1	< 0.1	MG/L	Q	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER: NJ0005622
 MONITORED LOCATION: 485A SW Outfall 485A
 MONITORING PERIOD: 10/1/2004 TO 10/31/2004
 FACILITY NAME: PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, °C	SAMPLE MEASUREMENT	*****	*****		*****	27.5	34.5		Q	1/DAY	CONTIN
00010 1	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	06431		PA 343	17451					
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>1</td><td>2004</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>10</td><td>31</td><td>2004</td></tr></table>	Month	Day	Year	10	1	2004	Month	Day	Year	10	31	2004	486A – SW Outfall 486A
Month	Day	Year												
10	1	2004												
Month	Day	Year												
10	31	2004												

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:

PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☐

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

11/19/2004

856-339-2900

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

486A SW Outfall 486A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC


PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	350	458	MGD	*****	*****	*****	*****	0	1/DAY	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.6	SU	0	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.8	SU	0	1/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE=N	CODE=N	MG/L	0	CODE=N	CODE=N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	27.6	32.3	DEG.C	0	1/DAY	CONTIN
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/Day	CONTIN
	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER: NJ0005622
 MONITORED LOCATION: 486A SW Outfall 486A
 MONITORING PERIOD: 10/1/2004 TO 10/31/2004
 FACILITY NAME: PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Lab Certification #											
99999 99	SAMPLE MEASUREMENT	17327	06431		PA343	17451					
Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applicable	NOT AP
	QL				*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	487B – SW Outfall 487B
	10	1	2004		10	31	2004	

PERMITTEE:

PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:


PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☒ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations	N/A	
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)	
	11/19/2004	856-339-2900
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE	AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	489A – SW Outfall 489A
	10	1	2004		10	31	2004	

PERMITTEE:
PSE&G NUCLEAR LLC
PO BOX 236/N21
ALLOWAY CREEK NEAK RD
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G NUCLEAR LLC
ALLOWAY CREEK NECK RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

REPORT RECIPIENT:
PSE&G NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☐

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

Michael H. Brothers, Vice President Operations

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

489A SW Outfall 489A

10/1/2004 TO 10/31/2004

PSEG NUCLEAR LLC

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.0975	0.0975	MGD	*****	*****	*****	*****	0	1/Month	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Month	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.3	SU	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	2	2	*****	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		100 01DAMX	30 01MOAV	*****			1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Petroleum Hydrocarbons 00551 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.5	<0.5	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX			1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	13	13	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX			1/Month	GRAB
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		P/A 343	17451					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".