

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

December 2, 2004

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 04-731A
NL&OS/GDM R0
Docket No. 50-281
License No. DPR-37

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
SURRY POWER STATION UNIT 2
WITHDRAWAL OF PROPOSED EMERGENCY TECHNICAL SPECIFICATION
CHANGE FOR ONE TIME EXTENSION OF THE ALLOWED OUTAGE TIME FOR
TWO INOPERABLE AUXILIARY FEED WATER PUMPS ON THE OPPOSITE UNIT

In a November 30, 2004 letter (Serial No. 04-731), Dominion requested an emergency amendment of the Facility Operating License, in the form of changes to the Technical Specifications (TS) to Facility Operating License Number DPR-37 for Surry Power Station Unit 2. Surry Unit 2 entered the 14-day Allowed Outage Time of TS 3.6.G.1 at 1130 hours on November 17, 2004 for two inoperable Auxiliary Feedwater (AFW) pumps on the opposite unit. The proposed change requested a revision to TS 3.6.G.1 to permit a one-time 7-day extension of the 14-day Allowed Outage Time to complete the repair of the Unit 1 motor driven AFW pump 1-FW-P-3B. However, maintenance activities for repair, testing and return to service of the pump were completed within the 14-day Allowed Outage Time and the pump was returned to service at 0755 hours on November 30, 2004. Therefore, Dominion is withdrawing the proposed emergency Technical Specifications change.

If you have any further questions or require additional information, please contact Mr. Gary D. Miller at (804) 273-2771.

Very truly yours,



Leslie N. Hartz
Vice President – Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Commissioner
Bureau of Radiological Health
1500 East Main Street
Suite 240
Richmond, VA 23218

Mr. N. P. Garrett
NRC Senior Resident Inspector
Surry Power Station

Mr. S. R. Monarque
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8-H12
Rockville, MD 20852