

December 3, 2004

Mr. Randall K. Edington  
Vice President-Nuclear and CNO  
Nebraska Public Power District  
P. O. Box 98  
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION – REQUEST FOR ADDITIONAL  
INFORMATION ON RELIEF REQUEST RI-35, REPAIR OF REACTOR  
PRESSURE VESSEL CONTROL ROD DRIVE NOZZLE-TO-CAP WELD  
(TAC NO. MC4954)

Dear Mr. Edington:

By letter dated October 25, 2004, Nebraska Public Power District (NPPD) requested the NRC staff to approve a request for relief as an alternative to the existing ASME Boiler and Pressure Vessel Code, Section XI requirements for the repair and examination of Class 1 welds.

The NRC staff has reviewed the information provided in the submittal and determined that the additional information identified in the enclosure is required in order for the NRC staff to complete its review. As agreed upon with Dave VanDerKamp on December 2, 2004, NPPD will respond to the NRC staff's request for additional information within 30 days from the date of this letter.

Sincerely,

**/RA/**

Michelle C. Honcharik, Project Manager, Section 1  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

December 3, 2004

Mr. Randall K. Edington  
Vice President-Nuclear and CNO  
Nebraska Public Power District  
P. O. Box 98  
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION – REQUEST FOR ADDITIONAL  
INFORMATION ON RELIEF REQUEST RI-35, REPAIR OF REACTOR  
PRESSURE VESSEL CONTROL ROD DRIVE NOZZLE-TO-CAP WELD  
(TAC NO. MC4954)

Dear Mr. Edington:

By letter dated October 25, 2004, Nebraska Public Power District (NPPD) requested the NRC staff to approve a request for relief as an alternative to the existing ASME Boiler and Pressure Vessel Code, Section XI requirements for the repair and examination of Class 1 welds.

The NRC staff has reviewed the information provided in the submittal and determined that the additional information identified in the enclosure is required in order for the NRC staff to complete its review. As agreed upon with Dave VanDerKamp on December 2, 2004, NPPD will respond to the NRC staff's request for additional information within 30 days from the date of this letter.

Sincerely,

**/RA/**

Michelle C. Honcharik, Project Manager, Section 1  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

RidsNrrDlpmLpdiv (HBerkow)  
RidsNrrPMMHoncharik  
RidsAcraAcnwMailCenter  
RidsRgn4MailCenter (KKennedy)  
RidsNrrDeDpr (SWall)  
MHartzman

PDIV-1 r/f  
RidsNrrDlpmLpdiv1 (MWebb)  
RidsNrrLADJohnson  
RidsOgcRp  
RidsNrrDlpmDpr (BPham)  
GGeorgiev  
TChan

KManoly

ACCESSION NO: ML043380325

\*No substantive changes

OFFICE	PDIV-1/PM	PDIV-1/LA	EMEB-B/SC	EMCB-B/SC	PDIV-1/SC
NAME	MHoncharik	DJohnson	KManoly	TChan	MWebb
DATE	12/3/04	12/2/04	11/23/2004*	11/18/2004*	12/3/04

OFFICIAL RECORD COPY

## Cooper Nuclear Station

cc:

Mr. William J. Fehrman  
President and Chief Executive Officer  
Nebraska Public Power District  
1414 15<sup>th</sup> Street  
Columbus, NE 68601

Mr. Clay C. Warren  
Vice President of Strategic Programs  
Nebraska Public Power District  
1414 15th Street  
Columbus, NE 68601

Mr. John R. McPhail, General Counsel  
Nebraska Public Power District  
P. O. Box 499  
Columbus, NE 68602-0499

Mr. Paul V. Fleming  
Licensing Manager  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. Michael J. Linder, Director  
Nebraska Department of Environmental  
Quality  
P. O. Box 98922  
Lincoln, NE 68509-8922

Chairman  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
1824 N Street  
Auburn, NE 68305

Ms. Cheryl K. Rogers, Program Manager  
Nebraska Health & Human Services  
System  
Division of Public Health Assurance  
Consumer Services Section  
301 Centennial Mall, South  
P. O. Box 95007  
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Director  
of Intergovernmental Cooperation  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 218  
Brownville, NE 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

Jerry Uhlmann, Director  
State Emergency Management Agency  
P. O. Box 116  
Jefferson City, MO 65101

Chief, Radiation and Asbestos  
Control Section  
Kansas Department of Health  
and Environment  
Bureau of Air and Radiation  
1000 SW Jackson  
Suite 310  
Topeka, KS 66612-1366

Mr. Daniel K. McGhee  
Bureau of Radiological Health  
Iowa Department of Public Health  
401 SW 7<sup>th</sup> Street  
Suite D  
Des Moines, IA 50309

Mr. Scott Clardy, Director  
Section for Environmental Public Health  
P.O. Box 570  
Jefferson City, MO 65102-0570

Jerry C. Roberts, Director of Nuclear  
Safety Assurance  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

REQUEST FOR ADDITIONAL INFORMATION

RELIEF REQUEST RI-35, REPAIR OF REACTOR PRESSURE VESSEL

CONTROL ROD DRIVE NOZZLE-TO-CAP WELD

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

DOCKET NO. 50-298

1. The October 25, 2004, submittal states that the welder and welding procedures will be qualified to use the shielded metal arc welding process. However, the deposition of the Alloy 52 requires the use of the gas tungsten arc welding (GTAW) process. Is the licensee planning to use welder and welding procedures qualified to use the GTAW process? If so, explain the difference.
2. Provide a diagram/sketch showing the control rod drive return nozzle-to-cap weld and the proposed weld overlay configuration.
3. Section (g)(2) of Code Case N-504-2 specifies that the evaluation of the repaired weld consider residual stresses produced by the weld overlay with the other applied loads on the system. The effects of water backing on the repair weld shall be considered. Section (g)(3) of Code Case N-504-2 specifies that the welds and components meet the applicable stress limits of the construction code.
  - a. What is the construction code that was used to satisfy the evaluation requirements in Sections (g)(2) and (g)(3) of the Code Case?
  - b. Provide a description of the methodology used to determine residual stresses and shrinkage effects.
  - c. Provide a list and a description of the calculations used for determining the length and thickness of the weld overlay.
  - d. Provide a table comparing the current licensing basis primary and primary-plus-secondary stresses, and the primary and primary-plus-secondary stresses at the location of the highest stress regions resulting from the installation of the weld overlay. Show that the component and the weld meet the applicable stress limits of the Cooper construction code, as required by the Code Case.
  - e. Provide the largest ASME Section III fatigue cumulative usage factor and its location in the region with and without the weld overlay, considering all applicable thermal and mechanical transients.