



444 South 16th Street Mall
Omaha NE 68102-2247

December 6, 2004
LIC-04-0029

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: November 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPDP) submits the attached MOR for November 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

D. J. Bannister
Manager -Fort Calhoun Station

DJB/EPM/epm

Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE December 2, 2004
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: November 2004

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	720	7,776	222,644
Number of Hours Generator was On-line:	720	7,759	221,284
Unit Reserve Shutdown Hours:			
Net Electrical Energy Generated (MWh):	349964	3,709,042	96,235,145

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of November 2004.