

VYNPS
TABLE 3.2.6
(Cont'd)

POST-ACCIDENT INSTRUMENTATION

<u>Minimum Number of Operable Instrument Channels (Note 8)</u>	<u>Parameter</u>	<u>Type of Indication</u>	<u>Instrument Range</u>
1/valve	Safety Valve Position From Acoustic Monitor (Note 5)	Meter ZI-2-1A/B	Closed - Open
2	Containment High-Range Radiation Monitor (Note 6)	Meter RM-16-19-1A/B	1 R/hr-10 ⁷ R/hr
1	Stack Noble Gas Effluent (Note 7)	Meter RM-17-155	0.1 - 10 ⁷ mR/hr

VYNPS

TABLE 4.2.6

CALIBRATION REQUIREMENTS

POST-ACCIDENT INSTRUMENTATION
(Cont'd)

<u>Parameter</u>	<u>Calibration</u>	<u>Instrument Check</u>
Containment High-Range Radiation Monitor	Once/Operating Cycle	Once each day
Stack Noble Gas Effluent	Every Operating Cycle (a Functional Test to be performed quarterly)	Once each day