



**FPL**

DEC 15 2004

L-2004-284  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report - November 2004

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the November 2004 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Terry O. Jones  
Vice President  
Turkey Point Plant

RLE

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

TE24

DOCKET NO.: 50-250  
UNIT: Turkey Point Unit 3  
DATE: 12/03/2004  
COMPLETED BY: Ronald Everett  
TELEPHONE: (305) 246-6190

Reporting Period November, 2004

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	8.7	6477.8	209011
No. of hours generator was on line (service hours)	0	6396.7	206537.2
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	0	4463145	135267790

### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20040019	9/26/04	S	710.1	C	4	CYCLE 21 REFUELING OUTAGE
20040020	11/30/04	F	9.9	C	4	REFUELING EXTENSION

**(1) Reason**

A - Equipment Failure (Explain)  
B - Maintenance or Test  
C - Refueling  
D - Regulatory Restriction  
E - Operator Training/License Examination  
F - Administrative  
G -Operational Error (Explain)  
H -Other

**(2) Method**

1 - Manual  
2 - Manual Trip/Scram  
3 - Automatic Trip/Scram  
4 - Continuation  
5 - Other (Explain)

### Summary Of Monthly Operating Experience

Unit 3 has been shut down since September 26, 2004 and was down the entire month of November for the Cycle 21 refueling outage.

DOCKET NO.: 50-251  
 UNIT: Turkey Point Unit 4  
 DATE: 12/03/2004  
 COMPLETED BY: Ronald Everett  
 TELEPHONE: (305) 246-6190

Reporting Period November, 2004

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720	7998.9	207418.7
No. of hours generator was on line (service hours)	720	7945.5	202923.9
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	516763	5569556	134091124

#### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	

##### (1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

##### (2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

#### Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of November, 2004.