



REMOTE SHUTDOWN SWITCHING ARRGT.

TABLE "A" IC2018 REMOTE SHUTDOWN PANEL			
VALVE	REMOTE PANEL	SELECTOR SWITCH	CONTROL ROOM
HV-1F003B	HS-15103B2	HSS-15116A	HS-15103B1
HV-1F004B	HS-15104B2	HSS-15114A	HS-15104B1
HV-1F006A	---	HSS-15112B	HS-15106A
HV-1F006B	HS-15106B2	HSS-15113B	HS-15106B1
HV-1F006C	---	HSS-15112B	HS-15106C
HV-1F006D	---	HSS-15113B	HS-15106D1
HV-1F007B	HS-15107B2	HSS-15115A	HS-15107B1
HV-1F008	HS-15108B2	HSS-15113A	HS-15108B1
HV-1F009	HS-15109B2	HSS-15112B	HS-15109B1
HV-1F010B	HS-15110B2	HSS-15113B	HS-15110B1
HV-1F015B	HS-15115B2	HSS-15116A	HS-15115B1
HV-1F016B	---	HSS-15113B	HS-15116B
HV-1F017B	HS-15117B2	HSS-15114A	HS-15117B1
HV-1F024B	HS-15124B2	HSS-15114B	HS-15124B1
HV-1F027B	---	HSS-15115B	HS-15127B
HV-1F028B	HS-15128B2	HSS-15115A	HS-15128B1
HV-1F040	HS-15140A	HSS-15112B	HS-15140
HV-1F047B	HS-15147B2	HSS-15115B	HS-15147B1
HV-1F048B	HS-15148B2	HSS-15115B	HS-15148B1
HV-1F049	HS-15149A	HSS-15114A	HS-15149
HV-1F103B	HS-15113B1	HSS-15115B	HS-15113B
HV-1F104B	HS-15114B1	HSS-15116A	HS-15114B
HV-12603	HS-12603A	HSS-15112A	HS-12603
SV-12651	HS-12651A	HSS-15111B	HS-12651
SV-12605	HS-12605A	HSS-15114B	HS-12605

RHR ROOMS FLOODING ALARM

NOTES:
1. FOR NOTES AND REFERENCES SEE SHEET 1.

AE DRAWING NO.		PPL DRAWING NO.	
REFERENCE DRAWINGS			
18	REVISED PER CR 423211.	KSF REM	Vem
REV	DESCRIPTION	DR	CH
SUSQUEHANNA S. E. S.			
UNIT 1			
P&ID			
RESIDUAL HEAT REMOVAL			
AREA	ELEV	SCALE	
PPL CORP.			
PPL DRAWING NO.	SHEET NO.	REV. NO.	
E106256	3		
AE DRAWING NO.	SHEET NO.	18	
M-151	3		