



U.S. NUCLEAR REGULATORY COMMISSION  
**STANDARD REVIEW PLAN**  
OFFICE OF NUCLEAR REACTOR REGULATION

Section 5.2.5 REACTOR COOLANT PRESSURE BOUNDARY LEAKAGE DETECTION  
REVIEW RESPONSIBILITIES

Primary - Auxiliary Systems Branch (ASB)

Secondary - None

I. AREAS OF REVIEW

The reactor coolant pressure boundary (RCPB) leakage detection systems are designed to provide a means of detecting and to the extent practical, identifying the source of the reactor coolant leakage. The ASB reviews those areas of the SAR relating to the system design to determine its adequacy to perform the detection and monitoring function to assure conformance with the requirements of General Design Criteria 2 and 30. The ASB reviews the system design with respect to the following:

1. The system is capable of identifying to the extent practical, the source of the reactor coolant leakage.
2. The system is capable of separately monitoring and collecting leakage from both identifiable and unidentifiable sources.
3. The system is adequately equipped with indicators and alarms for each leakage detection system in the main control room, and readily permits qualitative interpretations of such indicators.
4. The system provides for the monitoring of systems connected to the RCPB for signs of intersystem leakage.

In addition, the ASB will coordinate other branches' evaluations that interface with the overall review of the system as follows:

The Instrumentation and Control Systems Branch (ICSB) and the Power Systems Branch (PSB) determine the adequacy of the design, installation, testing and inspection of electrical components (sensing, control, power) required for

Rev. 1 - July 1981

---

USNRC STANDARD REVIEW PLAN

Standard review plans are prepared for the guidance of the Office of Nuclear Reactor Regulation staff responsible for the review of applications to construct and operate nuclear power plants. These documents are made available to the public as part of the Commission's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Standard review plans are not substitutes for regulatory guides or the Commission's regulations and compliance with them is not required. The standard review plan sections are keyed to the Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants. Not all sections of the Standard Format have a corresponding review plan.

Published standard review plans will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience.

Comments and suggestions for improvement will be considered and should be sent to the U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Washington, D.C. 20555.

---

proper operation as part of their primary review responsibility for SRP Sections 7.5 and 8.3 respectively. The Equipment Qualifications Branch (EQB) reviews the seismic qualification of Category I instrumentation of mechanical and electrical equipment as part of its primary review responsibility for SRP Sections 3.10 and 3.11 respectively. The Containment Systems Branch (CSB) reviews the containment isolation capability of the system as part of its primary review responsibility for SRP Section 6.2.4. The Mechanical Engineering Branch (MEB) determines that the components and piping are designed in accordance with applicable codes and standards as part of its primary review responsibility for SRP Sections 3.9.1 through 3.9.3. The MEB, also, determines the acceptability of the seismic and quality group classifications for system components as part of its primary review responsibility for SRP Sections 3.2.1 and 3.2.2. The Materials Engineering Branch (MTEB) verifies that inservice inspection requirements are met for system components as part of its primary review responsibility for SRP Section 6.6, and upon request, verifies the compatibility of the materials of construction with service conditions. The review for Technical Specifications and Quality Assurance are coordinated and performed by the Licensing Guidance Branch and Quality Assurance Branch as part of their primary review responsibility for SRP Sections 16.0 and 17.0 respectively.

For those areas of review identified above as being reviewed as part of the primary review responsibility of other branches, the acceptance criteria and their methods of application are contained in the SRP sections corresponding to those branches.

## II. ACCEPTANCE CRITERIA

The acceptability of the design of the RCPB Leakage Detection Systems as described in the applicant's safety analysis report (SAR) is based on specific general design criteria and regulatory guides. The design of the system is acceptable if the integrated design of the system is in accordance with the following criteria:

1. General Design Criterion 2 as it relates to the capability of the systems to maintain and perform their safety functions following an earthquake. Acceptance is based on meeting the guidelines of Regulatory Guide 1.29, positions C-1 and C-2.
2. General Design Criterion 30 as it relates to the detection, identification and monitoring of the source of reactor coolant leakage. Acceptance is based on meeting the guidelines of Regulatory Guide 1.45, positions C-1 through C-9.

## III. REVIEW PROCEDURES

The procedures below are used during the construction permit (CP) review to determine that the design criteria and bases and the preliminary design as set forth in the preliminary safety analysis report meet the acceptance criteria given in subsection II of this SRP section.

For the operating license (OL) review, the procedures are utilized to verify that the initial design criteria and bases have been appropriately implemented in the final design as set forth in the final safety analysis report.

Upon request from the primary reviewer, the coordinating review branches will provide input for the areas of review stated in subsection II of this SRP section. The primary reviewer obtains and uses such input as required to assure that the review procedures are complete.

The reviewer will select and emphasize material from the procedures described below, as may be appropriate for a particular case.

1. The reviewer verifies that identified leakage will be collected in tanks or sumps where its rate of accumulation will be monitored to obtain an identified leak rate. The reviewer should establish that the identified leakage is not only collected and monitored, but also done in such a fashion as to prevent identified leakages from masking unidentified leaks.
2. The reviewer verifies that the provisions for collecting, detecting and monitoring unidentified leakage are separate from identified leakage. The floor drainage system is reviewed to assure that leakage will flow readily to the sump or tank where it is collected without getting held up in any "reservoirs." The containment air coolers are reviewed to assure that leakage from "hot" systems which flashes into water vapor is readily condensed and that the condensate flows directly to the sump.
3. The reviewer determines that all potential intersystem leakage paths have been identified by the applicant. The reviewer determines that the instrumentation used in each path is appropriate and adequate to provide positive indication of intersystem leakage in the affected system and provides adequate monitoring capability so the limits assumed in the accident analyses are not exceeded. Intersystem leak detection methods include radioactivity, pressure, temperature, flow and pressure relief valve actuation indications, and the water inventory balance method. Table I shows some of the systems that require intersystem leakage monitoring.
4. The reviewer verifies that the leakage detection systems will remain functional for all seismic events not requiring a shut down and that the airborne particulate radioactivity monitoring system (APM) remains functional when subjected to the safe shutdown earthquake (SSE).
5. The reviewer verifies that all of the leakage detection systems have readouts in the control room and are provided with alarms. Direct reading systems, such as sumps, will normally indicate in gpm. The indirect reading systems, such as the APM, will indicate in counts per minute. The reviewer determines that control room operators will have a chart or graph that permits rapid conversion of count rate into gpm, that conversion procedures take into account the isotope being monitored and the activity of the primary coolant, and that the plant will maintain a running record of background leakage, so that its effect may be factored out from any sudden increases in leak indication, which may be "unidentified" leakage and require prompt action. If monitoring is computerized, backup procedures should be available to the operator.

6. The reviewer verifies that the sensitivity and response of the detection system is acceptable over the entire range of expected plant operating conditions of which it is monitoring. The reviewer verifies that the instrumentation and methodology used to determine leak rates are adequate.
7. The reviewer determines that the radiation monitoring systems have a radioactive source built into the system (the SAR refers to this feature as a "check source") to permit operability testing and calibration during operation. The reviewer determines that provisions are made to test and calibrate the sump level detection system. He also determines that a method for calibrating the air cooler condensate flow system exists, wherever the radiation monitors are used, and that a method to calibrate them to RCPB leakage exists. The frequency of testing and calibration should be provided and justified. The reviewer also determines that periodic testing of the floor drainage system will be performed to check for blockage and ensure operability.

#### IV. EVALUATION FINDINGS

The reviewer verifies that sufficient information has been provided and his review supports conclusions of the following type, to be included in the staff's safety evaluation report:

The reactor coolant pressure boundary (RCPB) leakage detection system provides reliable monitoring of reactor coolant leakage from components of the reactor coolant pressure boundary by the use of combinations of atmospheric particulate monitors, radiogas monitors, level indicators and pressure, humidity and temperature indicators.

The leakage detection systems provided to detect leakage from components of the reactor coolant pressure boundary furnish reasonable assurance that structural degradation, which may develop in pressure-retaining components of the RCPB and result in coolant leakage during service, will be detected on a timely basis, so that corrective actions can be made before such degradation could become sufficiently severe to jeopardize the safety of the system, or before the leakage could increase to a level beyond the capability of the makeup system to replenish the coolant loss.

The staff concludes that the design of the RCPB leakage detection systems is acceptable and meets the requirements of General Design Criterion 2 with respect to the capability to maintain and perform their safety functions in the event of earthquakes, and General Design Criterion 30 with respect to the detection, identification and monitoring of the source of reactor coolant leakage. This conclusion is based on the following:

1. The applicant has met the requirements of General Design Criterion 2 with respect to the systems capability to maintain and perform their safety functions in the event of earthquakes by meeting regulatory positions C-1 and C-2 of Regulatory Guide 1.29, and

2. The applicant has met the requirements of General Design Criterion 30 with respect to the detection, identification, and monitoring of the source of reactor coolant leakage by meeting regulatory positions C-1 through C-9 of Regulatory Guide 1.45.

## V. IMPLEMENTATION

The following is intended to provide guidance to applicants and licensees regarding the NRC staff's plans for using this SRP section.

Except in those cases in which the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the method described herein will be used by the staff in its evaluation of conformance with Commission regulations.

Implementation schedules for conformance to parts of the method discussed herein as contained in the referenced regulatory guides.

## VI. REFERENCES

1. 10 CFR Part 50, Appendix A, Criterion 2, "Design Basis for Protection Against Natural Phenomena."
2. 10 CFR Part 50, Appendix A, Criterion 30, "Quality of Reactor Coolant Pressure Boundary."
3. Regulatory Guide 1.29, "Seismic Design Classification."
4. Regulatory Guide 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems."

**Table 1. Systems and Components Connected to Reactor Coolant System  
and Require Intersystem Leakage Monitoring**

**I. In PWRs:**

1. Accumulators
2. Safety Injection Systems (High and Low Pressure)
3. Pressurizer Relief Tank
4. Secondary Side of Steam Generators
5. Residual Heat Removal System (Inlet and Discharge)
6. Secondary Side of Reactor Coolant Pump Thermal Barriers
7. Secondary Side of Residual or Decay Heat Removal Heat Exchangers
8. Secondary Side of Letdown Line Heat Exchangers
9. Secondary Side of Reactor Coolant Pump Seal Water Heat Exchangers

**II. In BWRs:**

1. Safety Injection Systems (High and Low Pressure Core Spray and Coolant Injection Systems)
2. Residual Heat Removal System (Inlet and Discharge)
3. Reactor Core Isolation Cooling System
4. Steam Side of High Pressure Coolant Injection (BWR-4)
5. Secondary Side of Reactor Water Cleanup System Heat Exchangers
6. Secondary Side of Reactor Coolant Pump Integral Heat Exchangers
7. Secondary Side of Residual Heat Removal Heat Exchangers