

August 29, 2005

Mr. M. Nazar  
Senior Vice President and  
Chief Nuclear Officer  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

SUBJECT: D. C. COOK NUCLEAR POWER PLANT, UNITS 1 AND 2  
INFORMATION REQUEST FOR AN NRC HEAT SINK PERFORMANCE  
BASELINE INSPECTION

Dear Mr. Nazar:

On October 3, 2005, the U.S. Nuclear Regulatory Commission (NRC) will begin the required biennial inspection of heat sink performance at your D. C. Cook Nuclear Power Plant. This inspection will be performed in accordance with the NRC baseline inspection procedure 71111.07. The heat exchangers to be reviewed during the inspection are the emergency diesel generator heat exchangers.

In order to minimize the impact that the inspection has on the site and to ensure a productive inspection for both sides, we have enclosed a request for documents needed for the inspection. The documents have been divided into two groups. The first group lists information necessary in order to ensure the inspector is adequately prepared for the inspection. This information should be available to the Regional Office by no later than September 23, 2005. Insofar as possible, this information should be provided electronically to the lead inspector.

The second group of documents requested are those items which the inspector will review or need access to during the inspection. It is important that these documents be as complete as possible, in order to minimize the number of documents requested during the preparation week or during the onsite inspection.

The lead inspector for this inspection is Mr. Andrew Dunlop. We understand that our regulatory contact for this inspection is Mr. Rich Meister of your organization. If there are any questions about the material requested, or the inspection, please call the lead inspector at (630) 829-9726 or e-mail him at [axd7@nrc.gov](mailto:axd7@nrc.gov).

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

***/RA by Patricia Lougheed Acting for/***

Ann Marie Stone, Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket Nos. 50-315; 50-316  
License Nos. DPR-58; DPR-74

Enclosure: Initial Document Request

cc w/encl: J. Jensen, Site Vice President  
L. Weber, Plant Manager  
G. White, Michigan Public Service Commission  
L. Brandon, Michigan Department of Environmental Quality -  
Waste and Hazardous Materials Division  
Emergency Management Division  
MI Department of State Police  
D. Lochbaum, Union of Concerned Scientists

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

***/RA by Patricia Lougheed Acting for/***

Ann Marie Stone, Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket Nos. 50-315; 50-316  
License Nos. DPR-58; DPR-74

Enclosure: Initial Document Request

cc w/encl: J. Jensen, Site Vice President  
L. Weber, Plant Manager  
G. White, Michigan Public Service Commission  
L. Brandon, Michigan Department of Environmental Quality -  
Waste and Hazardous Materials Division  
Emergency Management Division  
MI Department of State Police  
D. Lochbaum, Union of Concerned Scientists

ADAMS Distribution:

HKN  
DWS  
RidsNrrDipmlipb  
GEG  
KGO  
BJK1  
DRPIII  
DRSIII  
PLB1  
JRK1

DOCUMENT NAME:ML052420396.wpd

X Publicly Available ☐ Non-Publicly Available ☐ Sensitive ☒ Non-Sensitive

To receive a copy of this document, indicate in the concurrence box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII	RIII	RIII	
NAME	ADunlop:tr	RLerch for EDuncan	PLougheed for AMStone	
DATE	08/29/05	08/29/05	08/29/05	

**OFFICIAL RECORD COPY**

## **Initial Document Request**

### **I. Information Requested Expeditiously**

The following information is requested to be provided as soon as possible, but no later than September 23, 2005, to support the biennial "Heat Sink Performance," inspection procedure 71111.07. Information should be provided for the selected heat exchangers: emergency diesel generator heat exchangers for both units. Insofar as possible, information should be provided electronically:

1. copies of the procedures used to monitor or inspect heat exchanger performance;
2. a list of issues, with a short description, associated with heat exchangers, heat sinks, silting, corrosion, fouling, or heat exchanger testing that are documented in your corrective action system (last five years); and
3. copy of system description and/or design basis document for the heat exchangers under review (as applicable).

### **II. Information Requested to be Available on First Day of Inspection**

We request that the following information be available to the inspector once he arrives on-site October 3, 2005:

1. copies of the two most recently completed tests confirming thermal performance for those heat exchangers which are performance monitored. Include documentation and procedures that identify the types, accuracy, and location of any special instrumentation used for these tests. (e.g., high accuracy ultrasonic flow instruments or temperature instruments). Include calibration records for the instruments used during these tests;
2. copy of the evaluations of data for the two most recent completed tests confirming the thermal performance of each heat exchanger;
3. copy of the calculation which establishes the limiting (maximum) design basis heat load which is required to be removed by each of these heat exchangers;
4. copy of the calculation which correlates surveillance testing results from these heat exchangers with design basis heat removal capability (e.g., basis for surveillance test acceptance criteria);
5. the clean and inspection maintenance schedule for each heat exchanger;
6. copy of the document describing the inspection results for the last two clean and inspection activities completed on each heat exchanger;

7. copy of the document which identifies the current number of tubes in service for each heat exchanger and the supporting calculation which establishes the maximum number of tubes which can be plugged in each heat exchanger;
8. copy of the document establishing the repair criteria (plugging limit) for degraded tubes which are identified in each heat exchanger;
9. copy of the design specification and heat exchanger data sheets for each heat exchanger;
10. copy of the vendor/component drawing for each heat exchanger;
11. copy of the calculations which evaluate the potential for water hammer or excessive tube vibration in the heat exchanger or associated piping;
12. copy of heat exchanger performance trending data tracked for each heat exchanger;
13. copies of those documents that describe the methods taken to control water chemistry in the heat exchangers;
14. copies of the documents that verify the following for the ultimate heat sink:
  - sufficient reservoir capacity;
  - provision to ensure freedom from clogging due to macrofouling (silt, dead mussel shells, debris, etc.);
  - provisions controlling for biotic fouling;
  - functionality during adverse weather conditions, e.g., icing or high temperatures; and
  - Recent inspection results for intake structure.

If the information requested above will not be available, please contact Andrew Dunlop as soon as possible at (630) 829-9726 or E-mail - axd7@NRC.gov.