

## REACTOR COOLANT SYSTEM

### SURVEILLANCE REQUIREMENTS (Continued)

---

In addition to the requirements of Specification 4.0.5, each Reactor Coolant Pump flywheel shall be inspected per the recommendations of Regulatory Position C.4.b of Regulatory Guide 1.14, Revision 1, August 1975. In lieu of Position C.4.b(1) and C.4.b(2), a qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle one-half of the outer radius or a surface examination (MT and/or PT) of exposed surfaces of the removed flywheels may be conducted at 20 year intervals.

4.4.10.1.2 Augmented Inservice Inspection Program for Steam Generator Channel Heads - The steam generator channel heads shall be ultrasonically inspected during each of the first three refueling outages using the same ultrasonic inspection procedures and equipment used to generate the baseline data. These inservice ultrasonic inspections shall verify that the cracks observed in the stainless steel cladding prior to operation have not propagated into the base material. The stainless steel clad surfaces of the steam generator channel heads shall also be visually inspected during the above outages. This may be accomplished by direct visual examination or by remote means such as television camera. If the visual examination, either direct or remote, reveals detectable cladding indications, a record shall be made by means of a video tape recording or photographs for comparison purposes.

## REACTOR COOLANT SYSTEM

### 3.4.11 STRUCTURAL INTEGRITY

#### ASME CODE CLASS 1, 2 and 3 COMPONENTS

#### LIMITING CONDITION FOR OPERATION

---

3.4.11.1 The structural integrity of ASME Code Class 1, 2 and 3 components shall be maintained in accordance with Specification 4.4.11.1.

APPLICABILITY: ALL MODES.

ACTION:

- a. With the structural integrity of any ASME Code Class 1 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature more than 50°F above the minimum temperature required by NDT considerations.
- b. With the structural integrity of any ASME Code Class 2 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature above 200°F.
- c. With the structural integrity of any ASME Code Class 3 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) from service.
- d. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.4.11.1 In addition to the requirements of Specification 4.0.5, each Reactor Coolant Pump flywheel shall be inspected per the recommendations of Regulatory Position C.4.b of Regulatory Guide 1.14, Revision 1, August 1975. In lieu of Position C.4.b(1) and C.4.b(2), a qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle one-half of the outer radius or a surface examination (MT and/or PT) of exposed surfaces of the removed flywheels may be conducted at 20 year intervals.

4.4.11.2 Augmented Inservice Inspection Program for Steam Generator Channel Heads - The No. 21 Steam Generator channel head shall be ultrasonically inspected in a selected area during each of the first three refueling outages using the same ultrasonic inspection procedures and equipment used to generate the baseline data. These inservice ultrasonic inspections shall verify that the cracks observed in the stainless steel cladding prior to operation have not propagated into the base material.