

Robert Moody RE: Fwd: UCS comments following emergency preparedness meeting Page 1

From: "NELSON, Alan" <apn@nei.org>
To: "Nader Mamish" <NLM@nrc.gov>
Date: 9/7/05 2:16PM
Subject: RE: Fwd: UCS comments following emergency preparedness meeting

A couple thoughts:

1) Security Based EALs: The security based EALs are designed to supplement the existing set. The scenario described in the letter would still be driven as far as a GE if the radiological release were to exceed PAGs. Changing the definition of the vital area would add little other than a concurrent EAL situation.

2) Expedited NRC notification: I believe that the NRC should be notified within 15 minutes of classification (as discussed by the offsite agencies).

4) Informed Consent for Exposure to Bullets: How would we capture the statistical health effects and brief personnel in this instance?

5) ERO Augmentation: Was this a question?

6) Drill and Exercise Program: Drills and exercises are opportunities for both training and evaluation. The level of simulation while extensive does not provide the actual conditions of a real event. Trying to equate the consequences of a drill and that of an actual event are therefore not productive or practical. The ROP/CAP processes are working as evidenced in the performance indicators over the past several years.

7) SAE PARs: I agree, don't change them from what the State already has in place.

8) Spent Fuel Pool ERDS Points: Level and temp would be good.

9) Back-up siren power: Since sirens are a warning to go listen for information (not all siren systems are exclusively used for nuclear plant events), a wide scale power outage scenario would have many people without phone, TV or radio to do so. While back-up power is good, it is nothing more than one of several potential redundancies to help improve an already strong system.

-----Original Message-----

From: Nader Mamish [mailto:NLM@nrc.gov]
Sent: Wednesday, September 07, 2005 10:18 AM
To: NELSON, Alan
Subject: FYI: Fwd: UCS comments following emergency preparedness meeting

FYI

This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in error, please notify the sender immediately by

telephone or by electronic mail and permanently delete the original message.

Mail Envelope Properties (431F2E8A.039 : 10 : 4153)

Subject: RE: Fwd: UCS comments following emergency preparedness meeting
Creation Date: 9/7/05 2:16PM
From: "NELSON, Alan" <apn@nei.org>

Created By: apn@nei.org

Recipients

nrc.gov

twf2_po.TWFN_DO

NLM (Nader Mamish)

Post Office

twf2_po.TWFN_DO

Route

nrc.gov

Files

MESSAGE

Mime.822

Size

2431

4339

Date & Time

09/07/05 02:16PM

Options

Expiration Date:

None

Priority:

Standard

Reply Requested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard