

September 15, 2005

Mr. William O'Connor, Jr.
Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI POWER PLANT, UNIT 2 - INFORMATION REQUEST FOR AN NRC
BIENNIAL SAFETY SYSTEM DESIGN AND PERFORMANCE CAPABILITY
(SSDPC) BASELINE INSPECTION 05000341/2005016(DRS)

Dear Mr. O'Connor:

In our letter dated August 31, 2005, which announced our plans to begin a biennial Safety System Design and Performance Capability (SSDPC) baseline inspection at the Fermi 2 Power Plant, we stated that the reactor core isolation cooling and the emergency diesel generator systems were selected for review. However, in the enclosure, we did not state the reactor core isolation cooling system was selected. This was an error.

Enclosed is a revised request for documents needed for the inspection. As stated in our August 31, 2005 letter, these documents have been divided into three groups. The first group of information should be available to the NRC Region III office no later than October 27, 2005 and except as noted, should be provided electronically to Mr. Al Walker at (haw@nrc.gov). The second group of requested documents should be made available on-site for the inspectors by November 14, 2005. The third group lists information that will aid the inspection team in tracking issues identified as a result of the inspection. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the onsite portions of the inspection.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public

Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ann Marie Stone, Chief
Engineering Branch 2
Division of Reactor Safety

Docket No. 50-341
License No. NPF-43

Enclosure: Safety System Design and Performance Capability
Inspection (SSDPC) Document Request

cc w/encl: N. Peterson, Manager, Nuclear Licensing
D. Pettinari, Legal Department
Compliance Supervisor
G. White, Michigan Public Service Commission
L. Brandon, Michigan Department of Environmental Quality -
Waste and Hazardous Materials Division
Monroe County, Emergency Management Division
Planning Manager, Emergency Management Division
MI Department of State Police

Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ann Marie Stone, Chief
Engineering Branch 2
Division of Reactor Safety

Docket No. 50-341
License No. NPF-43

Enclosure: Safety System Design and Performance Capability
Inspection (SSDPC) Document Request

cc w/encl: N. Peterson, Manager, Nuclear Licensing
D. Pettinari, Legal Department
Compliance Supervisor
G. White, Michigan Public Service Commission
L. Brandon, Michigan Department of Environmental Quality -
Waste and Hazardous Materials Division
Monroe County, Emergency Management Division
Planning Manager, Emergency Management Division
MI Department of State Police

DOCUMENT NAME:ML052590523.wpd

☒ Publicly Available ☐ Non-Publicly Available ☐ Sensitive ☒ Non-Sensitive

To receive a copy of this document, indicate in the concurrence box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII		RIII		RIII			
NAME	HWalker:jb		EDuncan		AMStone			
DATE	9/15/05		9/15/05		9/15/05			

OFFICIAL RECORD COPY

ADAMS Distribution:

LXR1

NKR

RidsNrrDipmlipb

GEG

KGO

SJC4

DRPIII

DRSIII

PLB1

JRK1

SAFETY SYSTEM DESIGN AND PERFORMANCE CAPABILITY INSPECTION (SSDPC) DOCUMENT REQUEST

Inspection Report: 05000341/2005016(DRS)

Inspection Dates: November 14 through December 2, 2005

Inspection Procedure: IP 71111.21, "Safety System Design and Performance Capability"

Lead Inspector: Hershell Walker, Team Leader
(630) 829-9728

I. Information Requested for In-Office Preparation Week

The following information is requested by October 27, 2005, or sooner, to facilitate the selection of specific items that will be reviewed during the on-site inspection week. The team will select specific items from the information requested below and submit a list to your staff by November 8, 2005. We request that the specific items selected from the lists be available and ready for review on the first day of inspection. If you have any questions regarding this information, please call the team leader as soon as possible. All information should be sent, **electronically** if at all possible, to (haw@nrc.gov).

The items requested below apply **only** to the selected systems:

Reactor Core Isolation Cooling (RCIC) system and

Emergency Diesel Generators (EDGs) and associated support systems
(e.g., EDG Air Start, EDG Lube Oil, EDG Fuel Oil, EDG Jacket Water Cooling,
and EDG Room Cooling, EDG Service Water);

- (1) one copy of the systems' description, design basis documents, related training manuals and system health reports;
- (2) one copy of the normal and abnormal operating procedures;
- (3) five half-size (18" x 24") copies of the piping and instrument drawings (P&IDs) [paper copies];
- (4) two half-size (18" x 24") copies of the electrical schematics, single-line and key diagrams [paper copies];
- (5) name and phone numbers of the technical contact, a regulatory contact, and the design and system engineer(s);
- (6) current management and engineering organizational chart; and
- (7) list of analyses that either support or take credit for operation of the systems. For each analysis, besides the number and title, include the purpose of the

Enclosure

calculation, the date, a technical contact, and the current status (active, superceded, historical). Clarify any abbreviations or acronyms and give word titles for any numbers (e.g., "residual heat removal inner containment isolation valve," rather than "RH-2301-45B").

In addition to the above, specifically identify (by number) the calculations that address each of the following areas. If a calculation cannot be identified for a particular area, please provide an explanation of why a calculation is not necessary:

- breaker and fuse coordination calculations;
- diesel loading calculations;
- instrument uncertainty calculations;
- room temperature environmental qualification calculations for major equipment;
- relay setting calculations;
- setpoint calculations for all technical specification or emergency operation procedure equipment;
- time delay calculations (for any component incorporating time delay features);
- undervoltage and degraded voltage calculations;
- voltage drop calculations for all major electrical components (motors, MOVs);
- check valve leakage criteria calculations;
- design basis (flow rates, levels, pressures, temperatures) confirmation calculations (including NSSS calculations);
- heat exchanger calculations;
- NPSH and total dynamic head calculations;
- operability determination support calculations;
- pressure transient/water hammer evaluations;
- pump minimum recirculation flow calculations;
- relief valve sizing calculations;
- tank over-pressurization calculations; and
- tank sizing calculations.

- (8) List of all major modifications or set-point changes made to the selected systems since pre-operational testing. Major changes are those that significantly affected the way the system operated, for example, replacement of major components, modification to electrical control logic, etc. Please include the number and title, the modification purpose (description), the date, the status (whether the calculation is active, canceled, superceded, or under revision) and a technical contact. Spell out abbreviations, or acronyms and give word titles for any numbers. Note if any of the modifications required prior NRC approval. One way to provide this information is by providing the first sheet of the modification (not the cover letter);
- (9) list of open temporary modifications, if any;
- (10) list of the selected systems' electrical equipment/components that have been removed from the licensee's EQ Program, if any;

Enclosure

- (11) list of condition reports (corrective action documents) involving the RCIC system or EDG and its support systems that are in one of the following categories. For each condition report, besides the number and title, clearly designate the status (open/closed), the importance ranking, the date initiated, the date closed (if applicable), the status of corrective actions, and a technical contact. (Note: it is not necessary to provide a separate list for each category.)
- any condition report initiated more than 2 years prior to the inspection that is still open;
 - any condition report (open or closed) initiated in the last 2 years that required an apparent or root cause analysis (i.e., Category 1 or 2 condition reports);
 - any condition report (open or closed) initiated in the last 2 years that required an operability determination (include determination); and
 - any condition report (open or closed) initiated in the last 2 years that related to problems with the quality of engineering (not system specific).
- (12) the corrective maintenance history of major components for the last 2 years;
- (13) list of operability evaluations as far back as retrievable. Include both those currently relied upon and those that were previously relied upon for operability; and
- (14) list of Engineering Related Operator Workarounds.

II. Information Requested to be Available on First Day of Inspection (November 14, 2005)

We request that the following information be available to the team once they arrive on-site. The team will select the specific documents that will be reviewed for items (1) through (5) by November 8, 2005. Some documents, such as the Updated Final Safety Analysis Report or the Technical Specification, do not need to be solely available to the team (i.e., they can be located in a reference library) as long as the team has ready access to them. However, they should be located prior to the inspection team arriving on-site such that if the team requests any of these documents they are available within a short time (i.e., less than 2 hours):

- (1) copies of the selected calculations indicated by subject area in Item I.7, excluding data files. Please review the calculations and also provide copies of referenced material (such as drawings, engineering requests, vendor letters);
- (2) copies of the selected MAJOR design changes, modifications, and set-point changes as indicated in Item I.8. For each modification, as a minimum provide the purpose, the 10 CFR 50.59 evaluation or screening, and the completed post-modification test;
- (3) copies of the selected condition reports (corrective action documents) indicated

Enclosure

in Item I.11, including any associated root/apparent cause analyses and operability determinations;

- (4) copies of selected operability evaluations indicated in Item I.13 and plans for restoring operability, if applicable;
- (5) copies of selected work-around evaluations indicated in Item I.14 and plans for resolution;
- (6) copies of any open temporary modifications;
- (7) an Index of the surveillances for ALL Technical Specification equipment completed during the last 2 years;
- (8) list of all maintenance, surveillance, and annunciator response procedures related to the systems. Include name as well as number. For the surveillance procedures, provide a cross-reference which shows how each technical specification requirement is being met;
- (9) one copy of each major equipment drawing (valves, pumps, tanks, strainers), including pump head curves (1/2 size, 18" x 24");
- (10) copies of isometric drawings for major flow paths (1/2 size);
- (11) copies of elementary diagrams (1/2 size);
- (12) index of wiring diagrams (1/2 size);
- (13) copies of loop drawings (1/2 size);
- (14) copies of instrumentation and control logic drawings (1/2 size);
- (15) maintenance history of major components for the last 2 years;
- (16) trend data on the EDG fuel oil transfer pumps and RCIC pump performance (over last 3 years) including inservice testing, other vibration monitoring, oil sample results, etc., as applicable;
- (17) inservice testing valve tables for RCIC and EDG and support systems;
- (18) inservice testing basis document for RCIC and EDG and support systems (if available);
- (19) a copy of any self-assessments and associated corrective action documents generated in preparation for the inspection;
- (20) one copy of the current plant organization charts; and

Enclosure

- (21) reference materials (make available if needed):
- equipment qualification binders;
 - general set of plant drawings;
 - IPE/PRA report;
 - pre-operational tests, including documents showing resolution of deficiencies;
 - procurement documents for major components in each system (verify retrievable);
 - relevant operating experience information (such as vendor letters or utility experience);
 - standards used in system design (such as IEEE, ASME, TEMA);
 - system procedures;
 - Technical Specifications;
 - Technical Data Book (if applicable);
 - Updated Final Safety Analysis Report; and
 - vendor manuals.

III. *Information Requested to be provided throughout the inspection*

- (1) copies of any corrective action documents generated as a result of the team's questions or queries during this inspection; and
- (2) copies of the list of questions submitted by the team members and the status/resolution of the information requested (provide daily during the inspection to each team member).

If you have questions regarding the information requested, please contact the team leader.

Enclosure