

Release
RI

From: Anne Passarelli
To: Scott Barber
Date: 4/29/04 10:12AM
Subject: all about Thursday.

First of all, the Alleg Panel is at 9:30am Friday. Randy will attend. All the alleg office is aware.

As for status, Fred Bower helped me on the call. Larry D. and Dave Werkheiser piped up at the 8:00 (Glenn did also) on issues. There was a 24-hour report on the diesel driven fire pump at HC. In Feb, the surveillance resulted in out-of-spec viscosity for the oil. It was not realized until April 27th at which time the fire pump was declared inop. The pump is available, no risk issue. Dave Werkhieser was given the follow up for John Rogge, who didn't seem too concerned. As of this morning, the oil sample was being rerun. Comp action in place - X tie to Salem Fire System.

On Friday, Brian will be looking for info on:

Salem Midloop schedule

These 3 priority items - SBM switches/CTMT Spray piping issue (operability)/Hope Creek min flo vlv.

The min flo vlv situation was added to the main white board in the DRP Conf room as an "item."

See the e-mail from Dan for good info on the SBM switches.

635

f -