



SEP 13 2005

L-2005-197
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report – August 2005

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the August 2005 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Terry O. Jones
Vice President
Turkey Point Plant

RLE

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 9/7/2005
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period August, 2005

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	5738	215351.7
No. of hours generator was on line (service hours)	744	5670.4	212746.2
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	502862	3974244	139512909

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power for the month of August. On August 6, 2005, power was reduced to 40% of rated power to perform scheduled turbine valve testing (TVT), waterbox cleaning, and steam generator feedwater pump maintenance. The Unit returned to 100% power on August 8, 2005 and remained at essentially 100% power the remainder of the month.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 9/7/2005
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period: August, 2005

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3929.3	212070.5
No. of hours generator was on line (service hours)	744	3789.22*	207430.52*
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	520838	2517119	137117870

* The year-to-date and cumulative generator on line hours reflect a 3.76 hour decrease in the previously reported June generator on line hours.

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2- Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of August.