

TABLE 3.3-10 (Continued)

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>
14. Intermediate Range Neutron Flux	2	1
15. Intermediate Range Neutron Flux Rate	2	1
16. Containment Isolation Valve Position*	2/Penetration	1/Penetration
17. Containment Enclosure Negative Pressure	2	1
18. Condensate Storage Tank Water Level**	2	1
19. Reactor Vessel Level Indication System	2	1
20. Containment Sump Isolation Valve Position***	2 (1 per valve)	1

*Applies to penetrations with 2 active valves in series. These valves are moved to the closed position by automatic signals.

**Calculated on basis of pressure sensed at suction to the Emergency Feedwater Pumps.

***Applies to CBS-V8 and CBS-V14 open indication on UL indicators.