

From: VRodriguez, JHernandez, MPatel (Veronica Rodriguez) *RT*
To: DRP; DRS; ORA; PM
Date: Mon, Jun 21, 2004 4:10 PM
Subject: DRPnews

Vermont Yankee Transformer Fire

At 6:50 am on Friday June 18, 2004 morning, Vermont Yankee declared an Unusual Event as a result of a fire in the main transformer (greater than 10 minutes in duration) and resultant reactor trip (generator load reject). The fire was eventually extinguished and declared out at 7:51 am.

The residents immediately responded to the event. The Region I Incident Response Center was staffed to support the residents and to follow the licensee's response to the fire. The NRC did not enter the Monitoring Mode.

For details visit the DRP web page ... <http://r1ntweb.nrc.gov/drp/Drp.htm>

CC: Alicia Williamson; Anna Buseman-Williams; Christopher Sydnor; Jeffrey Bream; Kate Smith; Laura Limata; Samuel Collins; Victoria Ford

C-99