

October 24, 2005

LICENSEE: Exelon Generation Company, LLC

FACILITY: Dresden Nuclear Power Station, Units 2 and 3

SUBJECT: MINUTES OF CONFERENCE CALL REGARDING DRESDEN MSSV  
SETPOINT TOLERANCE (RESPONSE TO LICENSE CONDITION 4 FROM  
JULY 30, 2004 AMENDMENT)

The conference call between NRC staff and Exelon Generation Company, LLC (Exelon or the licensee) was held on October 7, 2005, from 2:30 P.M. to 3:15 P.M., with the attendees listed in Attachment 1. The purpose of the meeting was to discuss information provided by the licensee in a letter dated October 29, 2004, as supplemented by letters dated April 15 and May 26, 2005, responding to a license condition (item 4) imposed by a license amendment approved on July 30, 2004. This amendment increased the number of main steam safety valves (MSSVs) required to be operable from eight MSSVs to eight MSSVs and one safety/relief valve (S/RV), and was based on a setpoint tolerance of +/-1 percent. The item 4 license condition required that the licensee submit, for NRC approval, values for the MSSV and S/RV setpoint tolerances and the tolerance uncertainty treatment methodology.

Specific subjects discussed in the conference call were:

1. Valve internals are inspected through Exelon's internal procedures, therefore, NRC staff does not need to impose inspection of valve internals as a license condition.
2. Rather than having NRC approve values for the MSSV and S/RV setpoint tolerances and the tolerance uncertainty treatment methodology as outlined in the license condition (item 4), Exelon requests that NRC approve the methodology only. If NRC approves the methodology, Exelon will submit a setpoint that is consistent with the methodology.
3. Exelon would like to demonstrate that the design basis analysis will use setpoints for each valve greater than the setpoints determined by the methodology, in order to be more conservative.

The staff decided to have internal discussions on subjects 2 and 3 above, and inform Exelon of the results.

Attachment: As stated

October 24, 2005

LICENSEE: Exelon Generation Company, LLC

FACILITY: Dresden Nuclear Power Station, Units 2 and 3

SUBJECT: MINUTES OF CONFERENCE CALL REGARDING DRESDEN MSSV  
SETPOINT TOLERANCE (RESPONSE TO LICENSE CONDITION 4 FROM  
JULY 30, 2004 AMENDMENT)

The conference call between NRC staff and Exelon Generation Company, LLC (Exelon or the licensee) was held on October 7, 2005, from 2:30 P.M. to 3:15 P.M., with the attendees listed in Attachment 1. The purpose of the meeting was to discuss information provided by the licensee in a letter dated October 29, 2004, as supplemented by letters dated April 15 and May 26, 2005, responding to a license condition (item 4) imposed by a license amendment approved on July 30, 2004. This amendment increased the number of main steam safety valves (MSSVs) required to be operable from eight MSSVs to eight MSSVs and one safety/relief valve (S/RV), and was based on a setpoint tolerance of +/-1 percent. The item 4 license condition required that the licensee submit, for NRC approval, values for the MSSV and S/RV setpoint tolerances and the tolerance uncertainty treatment methodology.

Specific subjects discussed in the conference call were:

4. Valve internals are inspected through Exelon's internal procedures, therefore, NRC staff does not need to impose inspection of valve internals as a license condition.
5. Rather than having NRC approve values for the MSSV and S/RV setpoint tolerances and the tolerance uncertainty treatment methodology as outlined in the license condition (item 4), Exelon requests that NRC approve the methodology only. If NRC approves the methodology, Exelon will submit a setpoint that is consistent with the methodology.
6. Exelon would like to demonstrate that the design basis analysis will use setpoints for each valve greater than the setpoints determined by the methodology, in order to be more conservative.

The staff decided to have internal discussions on subjects 2 and 3 above, and inform Exelon of the results.

Attachment: As Stated

**Accession Number: ML052850065**

OFFICE	PM:LPD3-2	LA:LPD3-2	SC:EMEB	SC:LPD3-2	PD:LPD3
NAME	MBanerjee	PCoates	DCF for SLee	GSuh	HNieh
DATE	10/18 /05	10/18/05	10/19/05	10/19/05	10/24/05

**OFFICIAL RECORD COPY**

LIST OF ATTENDEES  
DRESDEN CONFERENCE CALL  
OCTOBER 7, 2005

Maitri Banerjee, NRC  
Tanya Ford, NRC  
Gary Hammer, NRC  
Stacey Imboden, NRC

Sharon Eldridge, Exelon  
Jim Krueger, Exelon  
Ken Nicely, Exelon  
Bob Ryback, Exelon  
Rick Swart, Exelon  
Bob Testin, Exelon  
Hossein Youseffnia, Exelon