

**From:** Rick Ennis  
**To:** Ronda Daflucas  
**Date:** 10/14/05 4:34PM  
**Subject:** Re: FW: How about this...

Ronda,

Regarding the format, the only change I would make is to change the paragraph numbering from (1) and (2) to 1. and 2. with indenting similar to proposed condition 3.M.

We can discuss the technical change (i.e., 30 days for item 2) on Monday morning at 8:30 am (same bridge number I provided you in earlier email).

thanks,

Rick

>>> "Daflucas, Ronda" <rdafluc@entergy.com> 10/14/05 2:50 PM >>>

I can see where the rewrite that I provided you was not clear. How about this...

#### L. Transient Testing

(1) During the extended power uprate (EPU) power ascension test program and prior to exceeding 168 hours of plant operation at the nominal full EPU reactor power level, with feedwater and condensate flow rates stabilized at approximately the EPU full power level, Entergy Nuclear Operations, Inc. shall confirm through performance of transient testing that the loss of one condensate pump will not result in a complete loss of reactor feedwater.

(2) Within 30 days at nominal full-power operation following successful performance of the test in (1) above, through performance of additional transient testing, or analysis of the results of the testing conducted in (1) above, confirm that the loss of one reactor feedwater pump will not result in a reactor trip.

Ronda Daflucas

**Mail Envelope Properties (43501657.382 : 11 : 372)**

**Subject:** Re: FW: How about this...  
**Creation Date:** 10/14/05 4:34PM  
**From:** Rick Ennis

**Created By:** RXE@nrc.gov

<b>Recipients</b>	<b>Action</b>	<b>Date &amp; Time</b>
entergy.com		
rdafluc (Ronda Daflucas)		

<b>Post Office</b>	<b>Delivered</b>	<b>Route</b>
	Pending	entergy.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	2788	10/14/05 04:34PM

**Options**

**Auto Delete:** No  
**Expiration Date:** None  
**Notify Recipients:** Yes  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard

**To Be Delivered:** Immediate  
**Status Tracking:** Delivered & Opened