

From: "Daflucas, Ronda" <rdafluc@entergy.com>
To: "Rick Ennis" <RXE@nrc.gov>
Date: 10/14/05 12:33PM
Subject: DRAFT for discussion, only

Rick -

Following is a DRAFT proposed rewrite of "L: Transient testing" for discussion purposes:

During the [EPU]...[ENO] shall: (1) confirm through performance of transient testing that the loss of one condensate pump will not result in a complete loss of reactor feedwater. (2) Within 30 days at nominal full-power operation following successful performance of the test in (1) above, through performance of additional transient testing, or analysis of the results of the testing conducted in (1) above, confirm that the loss of one reactor feedwater pump will not result in a reactor trip.

Thanks,

Ronda

Mail Envelope Properties (434FDDC4.279 : 24 : 12921)

Subject: DRAFT for discussion, only
Creation Date: 10/14/05 12:32PM
From: "Daflucas, Ronda" <rdafluc@entergy.com>

Created By: rdafluc@entergy.com

Recipients

nrc.gov
owf4_po.OWFN_DO
RXE (Rick Ennis)

Post Office
owf4_po.OWFN_DO

Route
nrc.gov

Files	Size	Date & Time
MESSAGE	613	10/14/05 12:32PM
TEXT.htm	2134	
Mime.822	4621	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard