

From: "Daflucas, Ronda" <rdafluc@entergy.com>
To: "Rick Ennis" <RXE@nrc.gov>
Date: 10/14/05 2:51PM
Subject: FW: How about this...

I can see where the rewrite that I provided you was not clear. How about this...

L. Transient Testing

(1) During the extended power uprate (EPU) power ascension test program and prior to exceeding 168 hours of plant operation at the nominal full EPU reactor power level, with feedwater and condensate flow rates stabilized at approximately the EPU full power level, Entergy Nuclear Operations, Inc. shall confirm through performance of transient testing that the loss of one condensate pump will not result in a complete loss of reactor feedwater.

(2) Within 30 days at nominal full-power operation following successful performance of the test in (1) above, through performance of additional transient testing, or analysis of the results of the testing conducted in (1) above, confirm that the loss of one reactor feedwater pump will not result in a reactor trip.

Ronda Daflucas

Mail Envelope Properties (434FFE0E.F1E : 11 : 16158)

Subject: FW: How about this...
Creation Date: 10/14/05 2:50PM
From: "Daflucas, Ronda" <rdafluc@entergy.com>

Created By: rdafluc@entergy.com

Recipients

nrc.gov
owf4_po.OWFN_DO
RXE (Rick Ennis)

Post Office

owf4_po.OWFN_DO

Route

nrc.gov

Files	Size	Date & Time
MESSAGE	909	10/14/05 02:50PM
TEXT.htm	4175	
Mime.822	7159	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard